

INSERT PAGES
IMC CHAPTER 5

To be inserted between pages 40 & 41.

Comm 64.0506 Commercial kitchen grease ducts and exhaust equipment. (2)
JOINTS, SEAMS AND PENETRATIONS OF GREASE DUCTS. (a) This is a department alternative to the requirements, but not the exceptions, in IMC section 506.3.2: Joints, seams and penetrations of grease ducts may be made with any other means that provide a liquid-tight seal at 1500°F and that are listed and labeled for the application.

(b) This is a department rule in addition to the requirements in IMC section 506.3.2.1: Duct joints may also be flanged joints.

(bm) The requirements of section IMC 506.3.3.1 are not included as part of this chapter.