

INSERT PAGES  
IMC CHAPTER 6

To be inserted between pages 54 & 55.

**Comm 64.0601 General.** Substitute the following wording for the requirements in IMC section 601.2 Exception 1: Use of a corridor as a source of makeup air for exhaust systems in rooms that open directly onto such corridors shall be permitted provided that each such corridor is directly supplied with outdoor air at a rate greater than the rate of makeup air taken from the corridor.