

INSERT PAGES  
IMC CHAPTER 6

To be inserted between pages 58 & 59.

**Comm 64.0606 Smoke detection system control.** (1) This is a department informational note to be used under IMC section 606.2.1:

**Note: For DHFS licensed healthcare facilities as specified in chs. HFS 124, 131, 132, and 134, also refer to NFPA standard 90A section 4-4.2A for air handling units between 2,000 cfm and 15,000 cfm.**

(2) This is a department informational note to be used under IMC section 606.4:

**Note: For DHFS licensed healthcare facilities as specified in chs. HFS 124, 131, 132, and 134, also refer to NFPA standard 90A section 4-3.2 for smoke dampers isolating air handling units.**