

INSERT PAGES
IMC CHAPTER 7

To be inserted between pages 64 & 65.

Comm 64.0702 Inside air. Substitute the following wording for the requirements in IMC section 702.2: When the space providing air for combustion, ventilation and dilution of flue gases has a minimum volume of 250 cubic feet per 1,000 Btu per hour combined input rating of all appliances, the use of inside air for combustion shall be allowed.