

INSERT PAGES
IMC CHAPTER 7

To be inserted between pages 66 & 67

Comm 64.0710 Opening location and protection. Substitute the following wording for the requirements in IMC section 710.1: Mounting height of the combustion air intakes shall have the lowest side of outside air intake openings located at least 12 inches vertical from the adjoining grade level.