

INSERT PAGES
IBC CHAPTER 1

To be inserted immediately preceding page 1

Comm 62.0100 Administration. The requirements in IBC chapter 1 are not included as part of this code.

Note: The sections in this chapter are generally numbered to correspond with the section numbering in the IBC, e.g., s. Comm 62.0202 corresponds to IBC section 202.

Note: As used throughout this code, "not included as part of this code" is intended to convey that the referenced requirements are not incorporated herein, and therefore cannot be enforced through this code. However, local ordinances may include the referenced requirements, as specified in s. Comm 61.03.

Note: IBC section 101.2 addresses the scope of the IBC. For the scope of the Wisconsin Commercial Building Code, see s. Comm 61.02. Three or more attached townhouses, as referenced in an exception under IBC section 101.2, are included within the scope listed in s. Comm 61.02. Detached one- and two-family dwellings, as likewise referenced in an exception under IBC section 101.2, and elsewhere in the IBC, are not included within the scope listed in s. Comm 61.02, but are regulated in Wisconsin by chs. Comm 20 to 25, in accordance with subch. II of ch. 101, Stats.

INSERT PAGES
IBC CHAPTER 2

To be inserted between pages 10 & 11.

Comm 62.0202 Definitions.

Comm 62.0202(1) ADDITIONS. These are department definitions for this chapter in addition to the definitions in IBC section 202:

(a) "Air retarder" means a material or combination of materials collectively having a maximum air leakage rate of 0.06 cfm/ft.² at 0.30 in. H₂O, when tested in accordance with ASTM E 783, installed to resist air leakage into the exterior envelope.

Comm 62.0202(2) SUBSTITUTIONS. Substitute the following definitions for the corresponding definitions listed in IBC section 202:

(a) "Approved" means acceptable to the department.

Comm 62.0202(3) DELETIONS. The following terms and corresponding definitions in IBC section 202 are not included as part of this code: approved agency, approved fabricator, base flood, base flood elevation, certificate of compliance, design flood, design flood elevation, designated seismic system, dry floodproofing, existing construction, fabricated item, inspection certificate, label, lowest floor, manufacturer's designation, mark, special continuous inspection, special flood hazard area, special inspection, special periodic inspection, sprayed fire-resistant materials, start of construction, and structural observation.

INSERT PAGES
IBC CHAPTER 2

To be inserted between pages 12 & 13.

Comm 62.0202 Definitions.

Comm 62.0202(2) SUBSTITUTIONS. Substitute the following definitions for the corresponding definitions listed in IBC section 202:

(b) "Basement" means that portion of a building that is partly or completely below grade. See IBC definition for "Story Above Grade Plane" and IBC section 502.1.

To be inserted between pages 14 & 15.

Comm 62.0202 Definitions.

Comm 62.0202(1) ADDITIONS. These are department definitions for this chapter in addition to the definitions in IBC section 202:

(b) "High-piled combustible storage" means storage of combustible materials in closely packed piles, or on pallets, in racks or on shelves, where the top of storage is greater than 12 feet in height. When required by the fire code official, high-piled combustible storage also includes certain high-hazard commodities, such as rubber tires, Group A plastics, flammable liquids, idle pallets and similar commodities, where the top of storage is greater than 6 feet in height.

Comm 62.0202(2) SUBSTITUTIONS. Substitute the following definitions for the corresponding definitions listed in IBC section 202:

(c) "Historic building" means a "qualified historic building" as defined in _____ s. 101.121(2)(c), Stats.

Note: Section s. 101.121(2)(c), Stats. reads as follows:

“Qualified historic building' means an historic building which:

"1. Is listed on, or nominated by the state historical society for listing on, the national register of historic places in Wisconsin;

"2. Is included in a district which is listed on, or has been nominated by the state historical society for listing on, the national register of historic places in Wisconsin, and has been determined by the state historical society to contribute to the historic significance of the district;

"2m. Is determined by the State Historical Society to be eligible for listing on the national Register of Historic Places in Wisconsin or the state Register of Historic Places.

"3. Is listed on a certified municipal register of historic property; or

"4. Is included in a district which is listed on a certified municipal register of historic property, and has been determined by the municipality to contribute to the historic significance of the district."

INSERT PAGES
IBC CHAPTER 3

To be inserted between pages 32 and 33

Comm 62.0307 Pyrophoric materials. This is a department informational note to be used under IBC section 307.4:

Note: See ch. Comm 14 for additional requirements for pyrophoric materials.

INSERT PAGES
IBC CHAPTER 3

To be inserted between pages 34 and 35

Comm 62.0310 Use and occupancy classification. This is a department informational note to be used under IBC section 310.2:

Note: See s. Comm 61.02 Notes for statutory definitions of adult family home and community-based residential facility. See s. Comm 61.04 for definitions of dwelling unit and multifamily dwelling.

INSERT PAGES
IBC CHAPTER 4

To be inserted between pages 36 & 37.

Comm 62.0400 Special detailed requirements based on use and occupancy. These are department rules in addition to the requirements in IBC chapter 4:

(1) FIREWORKS, BLACK POWDER AND EXPLOSIVE MATERIALS. Fireworks, black powder and explosive materials shall be stored and isolated in accordance with ch. Comm 14.

(2) RECYCLING SPACE. An owner of a building shall provide a separate room or designated space within or adjacent to the building for the separation, temporary storage and collection of recyclable materials that are likely to be generated by the building occupants, under any of the following conditions:

The construction of a new building.

Note: See Appendix B for guidelines for recommended designated areas.

Note: The collection and temporary storage of recyclable materials that are flammable or combustible is regulated by ch. Comm 14. Storage of liquids that are flammable or combustible is regulated by ch. Comm 10. Owners of buildings where these materials are stored should consult those chapters for isolation, removal and storage standards.

(3) LUNCHROOMS. A space for eating lunches shall be provided in all places of employment where there is exposure to injurious dusts, toxic material and industrial poisons. Such space shall be physically separate from any location where there is exposure to toxic materials. Toilet rooms shall not be permitted to serve as lunchrooms.

(4) COMMUNITY-BASED RESIDENTIAL FACILITIES. A newly constructed building or portion thereof that is a community-based residential facility serving 5 to 8 unrelated adults shall comply with chs. Comm 20 to 25 instead of all other requirements of this code.

Comm 62.0401 Chapter Comm 10 compliance. This is a department informational note to be used under IBC section 401.1:

Note: See ch. Comm 10 for additional requirements for motor vehicle service stations and for storage, handling, processing and transporting of flammable and combustible liquids.

Comm 62.0402 Lease plan. The requirements in IBC section 402.3 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 4

To be inserted between pages 44 & 45

Comm 62.0406 Motor vehicle-related occupancies.

PARKING GARAGES. Substitute the following wording for the requirements and exception in IBC section 406.2.8: Heating equipment shall be installed in accordance with the International Mechanical Code.

INSERT PAGES
IBC CHAPTER 4

To be inserted between pages 52 & 53

Comm 62.0412 Aircraft-related occupancies. Substitute the following wording for exception 1 in IBC section 412.2.4: Heating equipment that is suspended at least 10 feet above the upper surface of wings or engine enclosures of the highest aircraft which may be housed in the hangar; or at least 8 feet above the floor in shops, offices and other sections of the hangar communicating with storage or service areas.

INSERT PAGES
IBC CHAPTER 4

To be inserted between pages 54 & 55.

Comm 62.0414 Information required. The requirements in IBC section 414.1.3 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 4

To be inserted between pages 58 & 59.

Comm 62.0415 Hazardous materials.

(1) Substitute the following wording for the corresponding definition in IBC section 415.2: Immediately dangerous to life and health (IDLH). The concentration of air-borne contaminants which poses a threat of death, immediate or delayed permanent adverse health effects, or effects which could prevent escape from such an environment. This contaminant concentration level is established by the National Institute of Occupational Safety and Health based on both toxicity and flammability. It generally is expressed in parts per million by volume, or milligrams per cubic meter.

(2) This is a department rule in addition to the requirements in IBC section 415: A magazine for detonators in quantities of 100 or less shall have sides, bottoms and doors constructed of not less than number 12-gauge metal and lined with a nonsparking material. Hinges and hasps shall be attached so they cannot be removed from the outside. One steel padlock, which need not be protected by a steel hood, having at least 5 tumblers and a case hardened shackle of at least 3/8 inch diameter shall be provided for locking purposes.

INSERT PAGES
IBC CHAPTER 5

There are no modifications to IBC Chapter 5

INSERT PAGES
IBC CHAPTER 6

To be inserted between pages 86 & 87

Comm 62.0603 Allowable materials. Substitute the following wording for application 18 in IBC section 603.1: Sprayed fire-resistant materials and intumescent and mastic fire-resistant coating, determined on the basis of fire-resistance tests in accordance with Section 703.2

INSERT PAGES
IBC CHAPTER 7

To be inserted between pages 88 & 89.

Comm 62.0702 Fire separation distance. Substitute the following definition for the corresponding definition listed in IBC section 702: The distance measured from the building face to the closest interior lot line, to the centerline of a street alley or public way, to a permanent no-build easement line, or to an imaginary line between 2 buildings on the same property. The distance shall be measured at right angles from the lot line.

INSERT PAGES
IBC CHAPTER 7

To be inserted between pages 90 & 91.

Comm 62.0703 Fire-resistance ratings. Substitute the following wording for the requirements, but not the exception, in IBC section 703.2: The fire-resistance rating of building elements shall be determined in accordance with the test procedures set forth in ASTM E 119 or in accordance with IBC section 703.3. Materials and methods of construction used to protect joints and penetrations in fire-resistance-rated building elements shall not reduce the required fire-resistance rating.

Comm 62.0704 Connections between buildings. This is a department exception to the requirements in IBC section 704.1: This section does not apply to connections between buildings, that are in compliance with IBC section 3104.

INSERT PAGES
IBC CHAPTER 7

To be inserted between pages 94 & 95.

Comm 62.0705 Fire wall identification. These are department rules in addition to the requirements in IBC section 705:

(1) **PURPOSE.** Pursuant to s. 101.135 Stats., the purpose of this section is to establish uniform standards for the identification of fire walls on the exterior of buildings.

(2) **MUNICIPAL ORDINANCE.** A city, village or town may by ordinance require owners to identify the location of a fire wall at the exterior wall of a building with a sign.

(3) **SIGN REQUIREMENTS.**

(a) *General.* The sign shall consist of 3 circles arranged vertically on the exterior wall, marking the location of the fire wall and centered on the fire wall. The circles shall either be affixed directly to the surface of the building or may be placed on a background material that is affixed to the building.

(b) *Size of circle.* Each circle shall be the same size. The diameter of the circle shall be at least 1 1/2 inches, but no greater than 2 inches.

(c) *Spacing.* The circles shall be spaced an equal distance apart. The distance measured from the top of the uppermost circle to the bottom of the lowermost circle shall be no more than 12 inches.

(d) *Color.* The color of the circle shall be red, amber (orange-yellow) or white (clear) and shall be reflective. The color of the circle shall contrast with the color of the background.

INSERT PAGES
IBC CHAPTER 7

To be inserted between pages 98 & 99.

Comm 62.0707 Shaft Enclosures. (1). Substitute the following wording for the 7.2 exception in IBC section 707.2: Is not part of a required exit, except as permitted in section 1020.1.

(2) This is a department exception to the requirement in IBC section 707.2: Elevators in open parking garages that serve only the parking garage are not required to be enclosed.

INSERT PAGES
IBC CHAPTER 7

To be inserted between pages 110 & 111.

Comm 62.0716 Ducts and air-transfer openings. (1) PENETRATIONS OF SHAFT ENCLOSURES. This is a department exception to the requirements in IBC section 716.5.3: Smoke dampers are not required in ducts that are used in the exhaust portion of laboratory ventilating systems which are designed and installed in accordance with NFPA 45.

INSERT PAGES
IBC CHAPTER 7

To be inserted between pages 112 & 113.

Comm 62.0716 Ducts and air-transfer openings. (2) SMOKE DAMPERS IN HEALTH CARE FACILITIES. This is a department exception to the requirements in IBC section 716.5.5: Smoke dampers are not required in Group I-2 duct penetrations of smoke barriers in fully ducted HVAC systems.

INSERT PAGES
IBC CHAPTER 8

There are no modifications to IBC Chapter 8.

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 170 & 171.

Comm 62.0901 Fire protection systems. (1) MODIFICATIONS. Substitute the following informational note for the requirements in IBC section 901.3.

Note: Chapter Comm 14 has requirements relating to shutting down or impairing fire sprinkler systems. Chapter Comm 61 has requirements relating to availability of sprinkler documents and to submittal and approval of plans prior to altering, modifying, or removing sprinkler systems.

(2) FIRE HOSE THREADS. These are department informational notes to be used under IBC section 901.4:

Note: Section 213.15, Stats., regulates fire hose threads and fittings and reads as follows: "All fire hose fittings, apparatus fittings, 1.5 and 2.5 inches in diameter purchased or procured by a fire department or fire company shall be of the national standard hose thread as adopted by the national fire protection association. No fire department shall utilize hose and equipment not in conformance with the requirement that all threads shall be national standard hose thread as adopted by the national fire protection association. Any person offering for sale nonstandard hose couplings, fittings or apparatus fittings may be fined not less than \$100 nor more than \$500."

Note: NFPA 1963 contains the specifications for national standard hose thread.

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 171 & 172.

Comm 62.0902 Definition. Substitute the following definition and informational note for the corresponding definition listed in IBC section 902.1: "Automatic sprinkler system" or "Automatic fire sprinkler system" has the meaning given in s. 145.01 (2), Stats.

Note: Section 145.01 (2), Stats., reads as follows: " `Automatic fire sprinkler system,' for fire protection purposes, means an integrated system of underground and overhead piping designed in accordance with fire protection engineering standards. The system includes a suitable water supply, such as a gravity tank, fire pump, reservoir or pressure tank or connection beginning at the supply side of an approved gate valve located at or near the property line where the pipe or piping system provides water used exclusively for fire protection and related appurtenances and to standpipes connected to automatic sprinkler systems. The portion of the sprinkler system above ground is a network of specially sized or hydraulically designed piping installed in a building, structure or area, generally overhead, and to which sprinklers are connected in a systematic pattern. The system includes a controlling valve and a device for actuating an alarm when the system is in operation. The system is usually activated by heat from a fire and discharges water over the fire area."

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 174 & 175.

Comm 62.0903 Automatic fire sprinkler systems. (1) ALTERNATIVE PROTECTION. Substitute the following wording for the requirements in IBC section 903.1.1: Alternative automatic fire-extinguishing systems complying with IBC section 904 shall be permitted in lieu of automatic sprinkler protection where recognized by the applicable standard.

(2) GROUP A1. Substitute the following wording for condition 3 in IBC section 903.2.1.1: None of the stories in which the fire area is located include a level of exit discharge.

(3) GROUP A2. Substitute the following wording for condition 3 in IBC section 903.2.1.2: None of the stories in which the fire area is located include a level of exit discharge.

(4) GROUP A3. Substitute the following wording for condition 3 in IBC section 903.2.1.3: None of the stories in which the fire area is located include a level of exit discharge.

(5) GROUP E. Substitute the following wording for the requirements, but not the exception, in IBC section 903.2.2: (a) Except as provided in par. (b), an automatic sprinkler system shall be provided for all Group E occupancies as follows:

1. Throughout all Group E fire areas greater than 20,000 square feet in area.
2. Throughout every story of educational buildings that is located below a story which includes the lowest level of exit discharge.

(b) An automatic sprinkler system is not required in any fire area , or in any story that is located below a story which includes the lowest level of exit discharge, where every classroom throughout the building has at least one exterior exit at ground level.

(6) GROUP R. Substitute the following wording for the requirements in IBC section 903.2.7: (a) Except as provided in pars. (b) to (d) an automatic sprinkler system installed in accordance with Section 903.3 shall be provided throughout all buildings with a Group R fire area

(b) An automatic fire sprinkler system need not be installed in a multifamily dwelling where the floor areas or the number of dwelling units do not exceed any of the thresholds established in Table 62.0903. The floor areas specified in the thresholds do not include any of the following:

1. Areas that are outside a building, as in the following:
 - a. Porches that are open to the outside atmosphere.
 - b. Exterior stairs.
 - c. Exterior platforms.
 - d. Exterior landings.
 - e. Exterior decks.
2. An attached garage that meets all of the following criteria:
 - a. Has a floor area of 600 square feet or less.
 - b. Serves a single dwelling unit.
 - c. Is accessed directly from the dwelling unit.
 - d. Is separated from the remainder of the building by at least 1-hour rated fire-resistive construction.

Note: Housing units that receive federal funding may be required by federal regulations to have sprinkler protection regardless of building size.

Note: See Appendix A for a listing of municipalities that the department believes have preexisting stricter sprinkler ordinances, and a listing of thresholds those municipalities may apply which are more restrictive than in Table 62.0903.

3. This paragraph does not apply after December 31, 2010.

Note: The application of paragraph (b) applies to plans submitted for department review prior to January 1, 2011 and subsequently approved. See s. Comm 61.36 concerning plan approval expirations and extensions.

Under s. Comm 61.36(2)(b), a request to extend the expiration of a plan approval for a one-time 2-year period may be granted by the secretary provided: 1) the approved plan is for a multifamily dwelling containing less than 11 dwelling units; 2) the original plan was submitted for department review prior to January 1, 2011; and 3) the request is submitted prior to expiration of the original plan approval. This type of extension is at the discretion of the secretary.

**Table 62.0903
Maximum Floor Areas and Number of Dwelling Units Where a Sprinkler System is Not Required in a Multifamily Dwelling**

Class of Construction	Total Floor Area of Non-dwelling Unit Portions (Common use areas, such as corridors, stairways, basements, cellars, vestibules, laundry rooms, pools, etc.)	Total Floor Area Within Individual Dwelling Units	Number of Units
Type IA	16,000 sq ft	16,000 sq ft	8 units
Type IB	12,000 sq ft		
Type IIA	8,000 sq ft		
Type IIB	5,600 sq ft		
Type III			
Type IV			
Type VA			
Type VB	4,800 sq ft		

(c) An automatic sprinkler system is installed in a multifamily dwelling may conform with sub. (14) provided the multifamily dwelling complies with all of the following:

1. The multifamily dwelling does not contain more than 4 dwelling units.
2. The multifamily dwelling is not more than 2 stories above grade plane in height.
3. The multifamily dwelling is not served by either a community water system or a municipal water system as defined under s. NR 811.02.

Note: Under NR 811.02 “community water system means a public water system which serves at least 15 service connections used by year-round residents or regularly serves at least 25 year-round residents. Any water system serving 7 or more homes, 10 or more mobile homes, 10 or more apartment units or 10 or more condominium units shall be considered a community water system unless information is provided by the owner indicating that 25 year-round residents will not be served.”

Note: Under s. NR 811.02 “municipal water system means a community water system owned by a city, village, county, town, town sanitary district, utility district, public inland lake and rehabilitation district, municipal water district or a federal, state, county or municipal owned institution for congregate care or correction, or a privately owned water utility serving the foregoing.”

- (d) 1. An automatic sprinkler system need not be installed in a townhouse provided the townhouse complies with all of the following:
- a. The townhouse is not more than 3 stories above grade plane in height.
 - b. The townhouse does not contain more than 20 dwelling units
 - c. The total gross floor area of all the individual dwelling units with the townhouse does not exceed 16,000 square feet.
2. Each dwelling unit within the townhouse is separated from other dwelling units by at least 2-hour fire-resistive-rated separation walls constructed in accordance with the requirements of Section 705 and do not contain any openings and plumbing equipment of mechanical equipment. The separation wall does not have to comply with the structural stability requirements of Section 705.2 and the horizontal continuity requirements of Section 705.5.
3. An automatic sprinkler system installed in a townhouse may conform with sub. (14) provided the townhouse complies with all of the following:
- a. The townhouse does not exceed more than 3 stories above grade plane in height.
 - b. Each dwelling unit within the townhouse is separated from other dwelling units by at least 2-hour fire-resistive-rated separation walls constructed in accordance with the requirements of Section 705 and do not contain any openings and plumbing equipment of mechanical equipment. The separation wall does not have to comply with the structural stability requirements of Section 705.2 and the horizontal continuity requirements of Section 705.5.
4. An automatic sprinkler system need not be installed in a townhouse provided the townhouse is constructed of at least 2-hour fire resistance as defined under s. 101.14(4m)(a)5m., Stats.

Note: Section 101.14(4m)(a)5m. reads “ ‘Two-hour fire resistance’ means 2-hour fire separations for all walls that separate dwelling units, exit corridors and exit stair enclosures and for all floors and ceilings so that the specified walls, floors and ceilings are capable of resisting fire for a period not shorter than 2 hours.

Comm 62.0903 Automatic fire sprinkler systems. (6m) STUDENT HOUSING.

These are department rules in addition to the requirements in IBC section 903.2.7:

(a) *Definition.* In this paragraph, "private student residential building" has the meaning as given under s. 101.14 (4) (b) 1m., Stats.

Note: Section 101.14 (4) (b) 1m., Stats., reads: "In this paragraph, "private student residential building" means a privately owned and operated residential building that has a capacity of at least 100 occupants, that is occupied by persons at least 80 percent of whom are enrolled in an institution of higher education, and that has attributes usually associated with a student residence hall or dormitory such as a food service plan or occupancy by a resident advisor."

(b) *Existing housing.* 1. Except as provided in subd.2., an automatic fire sprinkler system shall be provided by January 1, 2006 throughout every residence hall and dormitory greater than 60 feet in height, the initial construction of which was begun before April 26, 2000, that is owned or operated by the board of regents of the University of Wisconsin System.

2. An automatic fire sprinkler system shall be provided by January 1, 2008 throughout Ogg Residence Hall at the University of Wisconsin-Madison.

3. An automatic fire sprinkler system shall be provided by January 1, 2014 throughout every residence hall and dormitory greater than 60 feet in height, the initial construction of which was begun before January 7, 2006, that is owned or operated by an institution of higher education, other than a residence hall or dormitory owned or operated by the board of regents of the University of Wisconsin System.

4. An automatic fire sprinkler system shall be provided by January 1, 2014 throughout every private student residential building greater than 60 feet in height, the initial construction of which was begun before January 7, 2006.

5. An automatic fire sprinkler system shall be provided by January 1, 2014 throughout every student residential facility operated by a fraternity, sorority or other organization authorized or sponsored by an institution of higher education, the initial construction of which was begun before January 7, 2006

(c) *New housing.* 1. An automatic fire sprinkler system shall be provided throughout every residence hall and dormitory, the initial construction which is begun on or after April 26, 2000, that is owned or operated by the board of regents of the University of Wisconsin System.

2. An automatic fire sprinkler system shall be provided throughout every residence hall and dormitory, the initial construction which is begun on or after January 7, 2006, that is owned or operated by an institution of higher education, other than a residence hall or dormitory owned or operated by the board of regents of the University of Wisconsin System.

3. An automatic fire sprinkler system shall be provided throughout every student residential facility, operated by a fraternity, sorority or an organization authorized or sponsored by an institution of higher education, the initial construction of which is begun on or after January 7, 2006.

4. An automatic fire sprinkler system shall be provided throughout every private student residential building, the initial construction of which is begun on or after January 7, 2006.

INSERT PAGES
IBC CHAPTER 9

Comm 62.0903 Automatic fire sprinkler systems. (7) UNIVERSITY DORMITORIES. This is a department informational note to be used under IBC section 903.2.7.

Note: Section 101.14 (4) (b) 3., Stats., an automatic sprinkler system must be installed at the time of construction of each floor of any University of Wisconsin System residence hall or dormitory that is constructed after April 26, 2000, regardless of the height of the building.

(8) GROUP S2. Substitute the following wording for the requirements, but not the exception, in IBC section 903.2.9: An automatic sprinkler system shall be provided throughout buildings classified as enclosed parking garages in accordance with IBC section 406.4 where located beneath other groups.

(9) GROUP S2 EXCEPTION. This is an additional department exception to the requirements in IBC section 903.2.9: Enclosed parking garages for fire apparatus and fire department vehicles that are located beneath fire stations.

(10) COMMERCIAL PARKING GARAGE EXCEPTION. This is a department exception to the requirements in IBC section 903.2.9.1: Enclosed parking garages for fire apparatus and fire department vehicles where within the fire stations.

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 176 & 177.

Comm 62.0903 Automatic fire sprinkler systems. (11) BUILDINGS OVER 60 FEET IN HEIGHT. This is a department rule in addition to the requirements in IBC section 903.2.10.3: (a) Except as provided in par. (b), pursuant to s. 101.14 (4) (b) 1r., Stats., automatic fire sprinkler systems shall be installed throughout building and structures that are more than 60 feet in height.

(b) An automatic fire sprinkler system is not to be provided in any of the following buildings or structures that are more than 60 feet in height:

1. Airport control towers.
2. Open parking structures complying with IBC section 406.3.
3. Telecommunications equipment spaces used exclusively for telecommunications equipment, associated electrical power distribution equipment and standby engines, provided that those spaces or areas are required throughout with an automatic fire detection system in accordance with IBC section 907.2 and are separated from the remainder of the building with fire barriers consisting of 1-hour fire-resistance-rated walls and 3-hour fire-resistance-rated floor/ceiling assemblies.
4. Special industrial occupancies complying with the criteria outlined in IBC section 503.1.2.
5. Occupancies of Group F-2 when omission of the automatic fire sprinkler system is approved in accordance with s. Comm 61.22.

(12) EXEMPT LOCATIONS. Substitute the following wording for exempt location 2 in IBC section 903.3.1.1.1: Any room or space where sprinklers are considered undesirable because of the nature of the contents, where approved by the department.

(13) BALCONIES. Substitute the following wording for the requirements in IBC section 903.3.1.2.1: Sprinkler protection complying with NFPA 13 shall be provided for exterior balconies and ground-floor patios of dwelling units where the building is of Type V construction. Sidewall sprinklers that are used to protect such areas shall be permitted to be located such that their deflectors are within 1 inch to 6 inches below the structural members, and a maximum distance of 14 inches below the deck of the exterior balconies that are constructed of open wood joist construction.

(14) TNFPA 13D SPRINKLER SYSTEMS. (a) Substitute the following wording for the requirements in IBC section 903.3.1.3: Where allowed, automatic sprinkler systems in townhouses and multifamily dwellings shall be installed throughout in accordance with NFPA 13D, except as provided in par. (b).

(b) Multipurpose piping systems shall conform with s. Comm 82.40(3)(e)2.a. and b.

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 178 & 179.

Comm 62.0903 Automatic fire sprinkler systems. (15) TESTING AND MAINTENANCE. Substitute the following informational note for the requirements in IBC section 903.5:

Note: See ch. Comm 14 for requirements for inspection, testing, and maintenance of fire sprinkler systems.

Comm 62.0904 Alternative automatic fire-extinguishing systems. (1) Substitute the following wording and informational note for the requirements in IBC section 904.1: Automatic fire-extinguishing systems, other than automatic sprinkler systems, shall be designed and installed in accordance with the provisions of IBC section 904 and the applicable referenced standards.

Note: See ch. Comm 14 for requirements for inspection, testing, and maintenance of alternate automatic fire-extinguishing systems.

(2) These are department rules in addition to the requirements in IBC section 904: (a) *Water mist fire protection systems.* Where a water mist fire protection system is installed, it shall comply with NFPA 750.

(b) *Manual-wet sprinkler systems.*

1. *Where allowed.* A manual-wet sprinkler system may not be installed in a building unless all of the following conditions are met:

- a. There is no municipal water system available to serve the property.
- b. There is no provision under this code that requires the building or a portion of the building to have an automatic fire sprinkler system.
- c. The municipality where the building is to be located has an adopted ordinance that requires the installation of manual-wet sprinkler systems and requires these systems to meet the provisions of this subsection.

2. *General requirements.*

- a. A building protected with a manual-wet sprinkler system shall be considered un-sprinklered under all other code provisions.
- b. Each manual-wet sprinkler system shall be provided with a fire department connection. The fire department connection shall be installed in an accessible location acceptable to the fire chief.
- c. All above ground piping of the manual-wet sprinkler system shall be labeled as a "manual-wet sprinkler system." Labels shall be placed at the fire department connection; at all valves and hose outlets; and on the piping at intervals of not more than 25 feet and at each side where the piping passes through a wall, floor or roof.
- d. The manual-wet sprinkler system design and installation shall comply with the automatic fire sprinkler system requirements of NFPA 13 or NFPA 13R, as applicable, except that the system comprised of the pilot line, fire department connection and fire department apparatus is considered as the approved water supply for the system.
- e. A manual-wet sprinkler system shall be supplied with water through the fire department connection using fire department apparatus.

INSERT PAGES
IBC CHAPTER 9

f. The plumbing well, water service and pressure tank shall be of a size and capacity to supply the hydraulically most remote sprinkler with the required waterflow and pressure for a minimum of 10 minutes.

g. A pilot line shall be connected from the manual-wet sprinkler system to the plumbing water supply system at the well pressure tank. The pilot line shall be of a size that is adequate to supply the hydraulically most remote sprinkler in the system.

h. The connection of a manual-wet sprinkler system to a plumbing water supply system shall be protected against backflow conditions in accordance with ch. Comm 82.

i. The actuation of any sprinkler in the system shall operate the waterflow indicating device, which shall initiate a fire alarm within the building.

j. Upon actuation of the building fire alarm, a fire alarm signal shall be sent automatically to the fire department providing fire protection to the building.

3. *Installer qualifications.* The installation or alteration of a manual-wet sprinkler system shall be performed by a licensed individual as specified for the installation of an automatic fire sprinkler system under subch. V of ch. Comm 5.

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 182 & 183.

Comm 62.0907 Fire alarm and detection systems. (1) GENERAL. Substitute the following wording and informational note for the requirements in IBC section 907.1: IBC section 907 covers the application and installation of fire alarm systems and their components.

Note: See ch. Comm 14 for requirements for performance and maintenance of fire alarm systems and their components.

(2) CONSTRUCTION DOCUMENTS. The requirements in IBC section 907.1.1 are not included as part of this code.

(3) GROUP I. Substitute the following wording for the requirements, but not the exception, in IBC section 907.2.6: A manual fire alarm system shall be installed in Group I occupancies. An electrically supervised, automatic smoke detection system shall be provided throughout the occupancy, except as provided in IBC sections 907.2.6.1 to 907.2.6.3.

To be inserted between pages 184 & 185.

Comm 62.0907 Fire alarm and detection systems. (4) GROUP M. Substitute the following wording for the requirements, but not the exception, in IBC section 907.2.7: A manual fire alarm system shall be installed in Group M occupancies having an occupant load of 500 or more persons, or more than 100 persons above or below a story that includes the lowest level of exit discharge. The initiation of a signal from the manual fire alarm box shall initiate alarm notification appliances as required by IBC section 907.9.

(5) SMOKE ALARMS. These are department informational notes to be used under IBC section 907.2.10 (intro.):

Note: Section 101.145 (2) and (3) (a), Stats., addresses installation of smoke detectors and reads as follows: Section 101.145 (2) "A smoke detector required under this section shall be approved by underwriters laboratory."

(3) (a) "The owner of a residential building shall install any smoke detector required under this section according to the directions and specifications of the manufacturer of the smoke detector."

Note: Section 101.145 (4), Stats., addresses retroactivity requirements for buildings constructed prior to the effective date of this section. This statute section applies beyond the application of this code, as established in s. Comm 61.03 (2), and states "The owner of a residential building the initial construction of which is commenced before, on or after May 23, 1978, shall install and maintain a functional smoke detector in the basement and at the head of any stairway on each floor level of the building and shall install a functional smoke detector either in each sleeping room of each unit or elsewhere in the unit within 6 feet of each sleeping area and not in a kitchen."

Note: Under section 101.145 (1) (b), Stats., "sleeping area" means the area of the [dwelling] unit in which the bedrooms or sleeping rooms are located. Bedrooms or sleeping rooms separated by another use area such as a kitchen or living room are separate sleeping areas but bedrooms or sleeping rooms separated by a bathroom are not separate sleeping areas.

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 186 & 187.

Comm 62.0907 Fire alarm and detection systems. (6) PROTECTIVE COVERS.

Substitute the following wording for the requirements in IBC section 907.3.5: The building official is authorized to require the installation of listed manual fire alarm box protective covers to prevent malicious false alarms or provide the manual fire alarm box with protection from physical damage. The protective cover shall be transparent or red in color with a transparent face to permit visibility of the manual fire alarm box. Each cover shall include proper operating instructions.

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 188 & 189.

Comm 62.0907 Fire alarm and detection systems. (7) EMPLOYEE WORK AREAS.
Substitute the following wording for the requirements in IBC section 907.9.1.2: Where employee work areas have audible alarm coverage, the alarm system shall be designed so that visible notification appliances can be integrated into the system.

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 190 & 191.

Comm 62.0909 Smoke control systems. (1) INSPECTION AND TEST REQUIREMENTS. Substitute the following wording for the requirements in IBC section 909.3: In addition to the ordinary inspection and test requirements that buildings, structures and parts thereof are required to undergo, smoke control systems subject to the provisions of IBC section 909 shall undergo inspections and tests sufficient to verify the proper commissioning of the smoke control design in its final installed condition. The design submission accompanying the construction documents shall clearly detail procedures and methods to be used and the items subject to such inspections and tests. Such commissioning shall be in accordance with generally accepted engineering practice and, where possible, based on published standards for the particular testing involved.

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 194 & 195.

Comm 62.0909 Smoke control systems. (2) INSPECTIONS FOR SMOKE CONTROL. Substitute the following wording for the requirements in IBC section 909.18.8: Smoke control systems shall be tested by a qualified agency.

(3) SCOPE OF TESTING. Substitute the following wording for the requirements in IBC section 909.18.8.1: Inspections shall be conducted in accordance with the following:

- (a) During erection of ductwork and prior to concealment for the purposes of leakage testing and recording of device location.
- (b) Prior to occupancy and after sufficient completion for the purposes of pressure-difference testing, flow measurements, and detection and control verification.

(4) QUALIFICATIONS. Substitute the following wording for the requirements in IBC section 909.18.8.2: Inspection agencies for smoke control shall have expertise in fire protection engineering, mechanical engineering and certification as air balancers.

(5) REPORTS. Substitute the following wording for the requirements in IBC section 909.18.8.3: A complete report of testing shall be prepared. The report shall include identification of all devices by manufacturer, nameplate data, design values, measured values and identification tag or mark. The report shall be reviewed by the responsible registered design professional and, when satisfied that the design intent has been achieved, the responsible registered design professional shall seal, sign and date the report.

(6) REPORT FILING. Substitute the following wording for the requirements in IBC section 909.18.8.3.1: A copy of the final report shall be maintained and made available to the building official upon request.

(7) SYSTEM ACCEPTANCE. The requirements in IBC section 909.19 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 196 & 197.

Comm 62.0910 Smoke and heat vents, and draft curtains. (1) EXCEPTION.
Substitute the following wording for exception 1. in IBC section 910.1: Buildings protected by an approved automatic sprinkler system.

(2) GROUPS F1 AND S1. Substitute the following wording for the requirements, but not the exception, in IBC section 910.2.1: Buildings and portions thereof used as Group F-1 or S-1 occupancies having more than 50,000 square feet in area that is undivided by full-height walls having smoke resisting characteristics which are similar to those under IBC section 910.3.5.1.

INSERT PAGES
IBC CHAPTER 10

To be inserted between pages 204 & 205.

Comm 62.1004 Egress for outdoor areas. Substitute the following wording for the requirements, but not the exceptions, in IBC section 1004.8: Yards, patios, courts and similar outdoor areas accessible to and usable by the building occupants shall be provided with means of egress as required by this chapter. The occupant load of such outdoor areas shall be based on the anticipated use. Where outdoor areas are to be used by persons in addition to the occupants of the building, and the path of egress travel from the outdoor areas passes through the building, means of egress requirements for the building shall be based on the sum of the occupant loads of the building plus the outdoor areas.

INSERT PAGES
IBC CHAPTER 10

To be inserted between pages 206 & 207.

Comm 62.1007 Accessible means of egress. Substitute the following wording for the requirement under IBC section 1007.3 exception 3.: The clear width of 48 inches between handrails and the area of refuge is not required at exit stairways in buildings or facilities that are equipped throughout with an automatic sprinkler system installed in accordance with IBC section 903.3.1.1 or 903.3.1.2.

Comm 62.1008 Doors, gates and turnstiles. (1) CLEAR DOOR OPENINGS FOR NONACCESSIBLE STALLS. This is a department exception to the requirements in IBC section 1008.1.1: The clear door opening for a nonaccessible toilet stall, shower stall, or other similar compartment, may be less than 32 inches wide.

INSERT PAGES
IBC CHAPTER 10

To be inserted between pages 210 & 211

Comm 62.1008 Doors, gates and turnstiles. (2) DOOR ARRANGEMENT. This is a department exception to the requirements in IBC section 1008.1.7: Where ample maneuvering space exists between the doors such that use by an individual in a wheelchair will not block the operation of the doors.

INSERT PAGES
IBC CHAPTER 10

To be inserted between pages 212 & 213.

Comm 62.1009 Solid risers not required. Substitute the following wording for the exception 2. in IBC section 1009.3.3.: Solid risers are not required in Group I-3, F, H and S occupancies, other than areas of parking structures accessible to the public.

INSERT PAGES
IBC CHAPTER 10

To be inserted between pages 218 & 219.

Comm 62.1014 Exit Access. This is a department exception to the requirements in IBC section 1014.3: The length of a common path of egress travel requirements shall not be limited within townhouse dwelling units provided the townhouse complies with all of the following:

- (1) The townhouse does not exceed more than 3 stories above grade plane in height.
- (2) Each dwelling unit within the townhouse is separated from other dwelling units by at least 2-hour fire-resistive-rated separation walls constructed in accordance with the requirements of Section 705 and do not contain any opening and plumbing equipment or mechanical equipment. The separation wall does not have to comply with the structural stability requirements of Section 705.2 and the horizontal continuity requirements of Section 705.5.

INSERT PAGES
IBC CHAPTER 10

To be inserted between pages 220 & 221.

Comm 62.1015 Refrigerated spaces. Substitute the following wording for the exception in IBC section 1015.5: Where using refrigerants in quantities limited to the amounts based on the volume set forth in ch. Comm 45.

Comm 62.1016 Exit access travel distance. (1) Substitute the following wording for the requirements, but not the exceptions, in IBC section 1016.1: (a) Exits shall be so located on each story that the maximum length of exit access travel, measured from the most remote point within a story to the entrance to an exit along the natural and unobstructed path of egress travel, shall not exceed the distances given in Table 1016.1 (b) Where the path of exit access includes unenclosed stairways or ramps with the exit access, the distance of travel on such means of egress components shall also be included in the travel distance measurement. The measurement along stairways shall be made on a plane parallel and tangent to the stair tread nosings in the center of the stairway.

(2) Substitute the following wording for the exception 3. in IBC section 1016.1: In other than occupancy Groups H and I, the exit access travel distance to a maximum of 50 percent of the exits is permitted to be measured from the most remote point within a building to an exit using unenclosed stairways or ramps when connecting a maximum of 2 stories. The two connected stories shall be provided with at least two means of egress. Such interconnected stories shall not be open to other stories. The measurement along stairways shall be made on a plane parallel and tangent to the stair tread nosings in the center of the stairway.

(3) This is a department exception to the requirements in IBC section 1016.1: In other than occupancy Groups H and I, exit access travel distance is permitted to be measured from the most remote point within a building to an exit using unenclosed stairways or ramps in the first and second stories in building equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. The first and second stories shall be provided with at least two means of egress. Such interconnected stories shall not be open to other stories. The measurement along stairways shall be made on a plane parallel and tangent to the stair tread nosings in the center of the stairway.

To be inserted between pages 222 & 223.

Comm 62.1017 Corridor continuity. This is a department exception to the requirements in IBC section 1017.5: Other spaces or rooms constructed as required for corridors, and that are adjacent to a fire-resistance-rated corridor, shall not be construed as intervening rooms; and may be open to the corridor when all of the following are satisfied:

- (1) The spaces are not occupied for hazardous uses.
- (2) The spaces are not occupied for the incidental uses listed in IBC Table 508.2.
- (3) The spaces are arranged so as to not obstruct access to the required exits.

Comm 62.1019 Minimum number of exits. (1) Substitute the following wording for the requirements in IBC section 1019.1: All rooms and spaces within each story shall be provided with and have access to the minimum number of approved independent exits required by Table 1019.1 based on the occupant load of the story. For the purposes of this chapter, occupied roof shall be provided with exits as required for stories. The required number of exits from any story, basement or individual space shall be maintained until arrival at grade or the public way.

- (2) These are department exceptions to the requirements in IBC section 1019.1:
 - (a) As modified by Section 1015.1.
 - (b) As modified by Section 1019.2.
 - (c) Rooms and spaces within each story provided with and having access to a means of egress that complies with Exception 3 or 4 in Section 1016.1 shall not be required to be provided the minimum number of approved independent exits required by Table 1019.1 on each story.
 - (d) Buildings of Group I-3 occupancy that are used as guard towers, provided the towers are no higher than 2 stories above grade, accommodate no more than 10 occupants, and have a travel distance of no more than 75 feet.

INSERT PAGES
IBC CHAPTER 10

To be inserted between pages 224 & 225.

Comm 62.1020 Vertical exit enclosures. The exceptions 4., 8., and 9. in IBC section 1020.1 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 11

To be inserted between pages 234 & 235.

Comm 62.1101 Design. These are department rules in addition to the requirements in IBC section 1101.2 and ICC/ANSI A117.1 sections 1003 and 1004:

(1) TYPE A AND TYPE B UNITS. (a) *Circuit breakers.* Circuit breakers, when provided for use by tenants in occupancies with dwelling and sleeping units, shall comply with ICC/ANSI A117.1 section 309.2 and 309.3.

(b) *Doors and doorways.* A renter of a dwelling unit may request the landlord to install lever door handles on any doors inside the dwelling unit or install single-lever controls on any plumbing fixtures used by the renter. These controls shall be provided and installed by the landlord at no additional cost to the renter.

Note: These requirements are based language from s. 101.132 (2) (a) 4., Stats.

(2) R-2 OCCUPANCY TOILET AND BATHING ROOMS. (a) When toilet and bathing rooms are provided in dwelling units and sleeping units within an R-2 occupancy the rooms shall conform to ICC/ANSI A117.1 section 1004.11.3.2 and with the requirements specified under par. (b).

(b) The minimum clear floor space provided at bathtubs and transfer showers shall be designed to facilitate a person using a wheelchair to reach and operate the bathtub or transfer shower controls without entering the bathtub or transfer shower.

INSERT PAGES
IBC CHAPTER 11

To be inserted between pages 236 & 237.

Comm 62.1103 Scoping Requirements. (1) DETACHED BUILDINGS. The requirements in IBC section 1103.2.4 are not included as part of this code.

(2) LIMITED ACCESS SPACES. Substitute the following wording for the requirements in IBC section 1103.2.8: (a) Storage spaces that do not include permanent workstations, are infrequently accessed by employees, and are not open to the general public are not required to be accessible.

(b) Nonoccupiable spaces accessed only by ladders, catwalks, crawl spaces, freight elevators, very narrow passageways, or tunnels are not required to be accessible.

Comm 62.1104 Accessible route. (1) GOVERNMENT-OWNED OR -OPERATED FACILITIES. This is a department limitation to the exception in IBC section 1104.4, Exception 1.: Government-owned or –operated facilities that are outside the scope of sub. (2) and IBC section 1104.3.2.

(2) TWO STORY BUILDINGS OR FACILITIES. Substitute the following wording for exception 4. under IBC section 1104.4: Where a two story building or facility, including a government-owned or operated building or facility, has one story with an occupant load of five or fewer persons that does not contain public use space, that story shall not be required to be connected to the story above or below.

To be inserted between pages 238 & 239.

Comm 62.1107 General dwelling unit and sleeping unit exceptions. (1) GROUP I. (a) *Group I-1.* Substitute the following wording for the requirements, but not the exception, in IBC section 1107.5.1.2: In structures with three or more dwelling or sleeping units intended to be occupied as a residence, every dwelling and sleeping unit intended to be occupied as a residence shall be a Type B unit.

(b) *Group I-2 nursing homes.* Substitute the following wording for the requirement, but not the exception, in IBC section 1107.5.2.2: In structures with three or more dwelling or sleeping units intended to be occupied as a residence, every dwelling and sleeping unit intended to be occupied as a residence shall be a Type B unit.

(c) *Group I-2 hospitals.* Substitute the following wording for the requirement, but not the exception, in IBC section 1107.5.3.2: In structures with three or more dwelling or sleeping units intended to be occupied as a residence, every dwelling and sleeping unit intended to be occupied as a residence shall be a Type B unit.

(2) GROUP R. (a) *Group R-1.* Substitute the following wording for the requirement, but not the exception, in IBC section 1107.6.1.2: In structures with three or more dwelling or sleeping units intended to be occupied as a residence, every dwelling and sleeping unit intended to be occupied as a residence shall be a Type B unit.

To be inserted between pages 240 & 241.

Comm 62.1107 General dwelling unit and sleeping unit exceptions. (2) GROUP R.

(b) *Group R-2.* 1. ‘Apartment houses, monasteries and convents.’ Substitute the following wording for the requirement, but not the exception, in IBC section 1107.6.2.1.2: Where there are three or more dwelling units or sleeping units intended to be occupied as a residence in a single structure, every dwelling unit and sleeping unit intended to be occupied as a residence shall be a Type B unit.

2. ‘Boarding houses, dormitories, fraternity houses and sorority houses.’ Substitute the following wording for the requirement, but not the exception, in IBC section 1107.6.2.2.2: Where there are three or more dwelling units or sleeping units intended to be occupied as a residence in a single structure, every dwelling unit and sleeping unit intended to be occupied as a residence shall be a Type B unit.

(c) *Group R-4.* Substitute the following wording for the requirement, but not the exception, in IBC section 1107.6.4.2: In structures with three or more dwelling or sleeping units intended to be occupied as a residence, every dwelling and sleeping unit intended to be occupied as a residence shall be a Type B unit.

(3) SITE IMPRACTICALITY. (a) *Petition for variance.* This is a department rule in addition to the requirements in IBC section 1107.7.4: In accordance with ss. 101.132 (2) (b) 4. and (c) 2., Stats., the owner may request a reduction in the number of Type A or Type B dwelling units due to site impracticality through the petition for variance procedures specified in ch. Comm 61.

(b) *Condition.* Substitute the following wording for condition 1 under IBC section 1107.7.4: Not less than 50% of the units required by IBC section 1107.7.1 on the site are Type A or Type B units.

INSERT PAGES
IBC CHAPTER 11

To be inserted between pages 246 & 247.

Comm 62.1110 Signage. (1) PUBLIC PARKING. (a) *General.* Substitute the following wording for the requirements for location 1 in IBC section 1110.1: Except as specified par. (b), accessible parking spaces required in IBC section 1106 for the general public shall be identified with a sign complying with the accessible parking sign requirements specified in s. Trans 200.07.

(b) *Exceptions.* 1. 'Small parking facilities.' Accessible parking spaces required by IBC section 1106.1 are not required to be signed when the total number of parking spaces provided is four or less.

2. 'Employee and resident parking.' Accessible parking facilities identified for use only by employees of any building or facility or by tenants in Group R-2 occupancies may be identified with signs other than the s. Trans 200.07 signs.

(2) DIRECTIONAL AND INFORMATIONAL SIGNS. (a) Substitute the following wording for the introductory paragraph of IBC section 1110.3: Signs indicating directional information or information about functional spaces or signage indicating special accessibility provisions shall be provided as follows:

(b) This is a department informational note to be used under IBC section 1110.3.

Note: Refer to s. 101.123, Stats., for requirements for designating smoking areas.

INSERT PAGES
IBC CHAPTER 12

To be inserted between pages 250 & 251.

Comm 62.1204 Interior environment. Substitute the following wording for the requirements and exception in IBC section 1204.1: Interior spaces intended for human occupancy shall conform to the IMC.

Comm 62.1206 Court drainage. Substitute the following wording and informational note for the requirements in IBC section 1206.3.3: The bottom of every court shall be properly graded and drained.

Note: See ch. Comm 82 for requirements for storm water piping.

INSERT PAGES
IBC CHAPTER 12

To be inserted between pages 252 & 253.

Comm 62.1210 Toilet rooms. These are department rules in addition to the requirements in IBC section 1210.5: **(1) PRIVACY AND ACCESS.** Every toilet room shall be enclosed and separated from other areas of the building in a manner that will ensure privacy of the users of the toilet rooms. Restriction of access to toilet rooms, such as by use of key locks or other similar devices, is prohibited, except as provided in sub. 2.

(2) EXCEPTIONS.

(a) Toilet rooms for a service or filling station that are accessed from the exterior may be key locked.

(b) A self-service filling station that has a key- or card-operated fuel dispensing device which can be used while the station is unattended by an employee is not required to have toilet rooms available during the unattended periods.

(c) Single-occupant toilet rooms may have privacy locks.

To be inserted between pages 248 & 249.

Comm 62.1200 Carbon monoxide alarms. These are department rules in addition to the requirements in IBC chapter 12: (1) DEFINITIONS. In this section:

(a) “Dwelling unit” has the meaning as given in s. 101.61 (1), Stats.

Note: Section 101.61 (1) reads: “Dwelling unit” means a structure or that part of a structure which is used or intended to be used as a home, residence or sleeping place by one person or by 2 or more persons maintaining a common household, to the exclusion of all others.

(b) “Fuel–burning appliance” means a device that is installed in a building and burns fossil–fuel or carbon based fuel where carbon monoxide is a combustion by–product, including stoves, ovens, grills, clothes dryers, furnaces, boilers, water heaters, heaters, fireplaces and stoves.

(c) “Residential building” has the meaning as given in s. 101.149 (1) (b), Stats.

Note: Section 101.149 (1) (b) reads: “Residential building” means a tourist rooming house, a bed and breakfast establishment, or any public building that is used for sleeping or lodging purposes. “Residential building” does not include a hospital or nursing home.

(d) “Sealed combustion appliance” means a listed appliance that acquires all air for combustion through a dedicated sealed passage from the outside to a sealed combustion chamber and all combustion products are vented to the outside through a separate dedicated sealed vent.

(e) “Sleeping area” has the meaning as given in s. 101.145 (1) (b), Stats.

Note: Section 101.145 (1) (b) reads: “Sleeping area” means the area of the unit in which the bedrooms or sleeping rooms are located. Bedrooms or sleeping rooms separated by another use area such as a kitchen or living room are separate sleeping areas but bedrooms or sleeping rooms separated by a bathroom are not separate sleeping areas.

(2) INSTALLATION. (a) 1. Listed and labeled carbon monoxide alarms or detectors shall be installed at locations specified in s. 101.149 (2), Stats., and maintained in accordance with s. 101.149 (3), Stats., in buildings, including buildings existing on October 1, 2008, which are residential buildings or include residential buildings, and contain fuel–burning appliances, except as provided in subd. 4.

Note: Section 101.149 (2) and (3), Stats., reads:

(2) INSTALLATION REQUIREMENTS. (a) Except as provided in par. (b), the owner of a residential building shall install a carbon monoxide detector in all of the following places not later than the date specified under par. (c):

- 1. In the basement of the building if the basement has a fuel-burning appliance.**
 - 2. Within 15 feet of each sleeping area of a unit that has a fuel-burning appliance.**
 - 3. Within 15 feet of each sleeping area of a unit that is immediately adjacent to a unit that has a fuel-burning appliance.**
 - 4. In each room that has a fuel-burning appliance and that is not used as a sleeping area. A carbon monoxide detector shall be installed under this subdivision not more than 75 feet from the fuel-burning appliance.**
 - 5. In each hallway leading from a unit that has a fuel-burning appliance, in a location that is within 75 feet from the unit, except that, if there is no electrical outlet within this distance, the owner shall place the carbon monoxide detector at the closest available electrical outlet in the hallway.**
- (b) If a unit is not part of a multiunit building, the owner of the residential building need not install more than one carbon monoxide detector in the unit.**
- (c) 1. Except as provided under subd. 2., the owner of a residential building shall comply with the requirements of this subsection before the building is occupied.**
- 2. The owner of a residential building shall comply with the requirements of this subsection not later than April 1, 2010, if construction of the building was initiated before October 1, 2008, or if the department approved the plans for the construction of the building under s. 101.12, Stats., before October 1, 2008.**
- (d) Any carbon monoxide detector that bears an Underwriters Laboratories, Inc., listing mark or similar mark from an independent product safety certification organization satisfies the requirements of this subsection.**
- (e) The owner shall install every carbon monoxide detector required by this subsection according to the directions and specifications of the manufacturer of the carbon monoxide detector.**
- (3) MAINTENANCE REQUIREMENTS. (a) The owner of a residential building shall reasonably maintain every carbon monoxide detector in the residential building in the manner specified in the instructions for the carbon monoxide detector.**
- (b) An occupant of a unit in a residential building may give the owner of the residential building written notice that a carbon monoxide detector in the residential building is not functional or has been removed by a person other than the occupant. The owner of the residential building shall repair or replace the nonfunctional or missing carbon monoxide detector within 5 days after receipt of the notice.**
- (c) The owner of a residential building is not liable for damages resulting from any of the following:**
- 1. A false alarm from a carbon monoxide detector if the carbon monoxide detector was reasonably maintained by the owner of the residential building.**
 - 2. The failure of a carbon monoxide detector to operate properly if that failure was the result of tampering with, or removal or destruction of, the carbon monoxide detector by a person other than the owner or the result of a faulty alarm that was reasonably maintained by the owner as required under par. (a).**

INSERT PAGES
IBC CHAPTER 12

2. The installation of carbon monoxide alarms or detectors in accordance with s. 101.149 (2) and (3), Stats., shall be throughout the entire building where a portion of the building includes a residential building.
3. The installation of carbon monoxide alarms or detectors in adjacent units required under s. 101.149 (2) (a) 3., Stats., shall apply to those units located on the same floor level.
4. The 75-foot installation limit specified under s. 101.149 (2) (a) 5., Stats., shall be measured from the door of the unit along the hallway leading from the unit.
5. The installation of carbon monoxide alarms or detectors is not required in buildings if construction of the building was initiated before October 1, 2008, or if the department approved the plans for the construction of the building under s. Comm 61.30, provided the building does not have an attached enclosed garage and either of the following circumstances applies:
 - a. All of the fuel-burning appliances in the building are of a sealed-combustion type that are covered by the manufacturers' warranties against defects.
 - b. All of the fuel-burning appliances in the building are of sealed-combustion type that are inspected in accordance with sub. (3) or rules promulgated by the department of health services under s. 254.74 (1) (am), Stats.
 - (b) 1. Carbon monoxide alarms shall conform to UL 2034.
 2. Carbon monoxide alarms shall be listed and labeled identifying conformance to UL 2034.
 3. Carbon monoxide detectors and sensors as part of a gas detection or emergency signaling system shall conform to UL 2075.
 - (c) Carbon monoxide alarms to be installed in a building shall be wired to the building's electrical service and include battery secondary power supplies, if either of the following conditions applies:
 1. Plans for the construction of the building were submitted for review under s. Comm 61.30 on or after October 1, 2008.
 2. Construction of the building was initiated on or after October 1, 2008, if plans were not required to be submitted and approved under s. Comm 61.30.
 - (d) Carbon monoxide alarms to be installed within a dwelling unit shall be interconnected so that activation of one alarm will cause activation of all alarms within the dwelling unit, if either of the following conditions applies:
 1. Plans for the construction of the building were submitted for review under s. Comm 61.30 on or after October 1, 2008.
 2. Construction of the building was initiated on or after October 1, 2008, if plans were not required to be submitted and approved under s. Comm 61.30.

- (3) INSPECTION OF SEALED COMBUSTION APPLIANCES.** (a) The owner of a building or their agent shall arrange the inspection of sealed combustion appliances and the vents and chimneys serving the appliances under sub. (2) (a) 5. b.
- (b) Pursuant to sub. (2) (a) 5. b., the inspection of the sealed combustion appliances, vents and chimneys shall be for the purpose of determining carbon monoxide emission levels.
- (c) Pursuant to sub. (2) (a) 5. b., the inspection of the sealed combustion appliances, vents and chimneys shall be performed at least once a year.

INSERT PAGES
IBC CHAPTER 12

(d) For the propose of sub. (2) (a) 5. b., the inspection of the sealed combustion appliances, vents and chimneys shall be performed by an individual who holds a certification issued under s. Comm 5.73 as an HVAC qualifier.

(e) If upon inspection, the carbon monoxide emissions from a fuel burning appliance, vent or chimney are not within manufacturer's specifications, the appliance may not be operated until repaired or carbon monoxide alarms or detectors are installed in accordance with s. 101.149 (2) and (3), Stats.

(4) ORDERS. Pursuant to s. 101.149 (6) (b), Stats., the department may issue orders for a violation of the provisions of this section.

(5) PENALTIES. Violation of the provisions of this section shall be subject to the penalties provided under s. 101.149 (8), Stats.

Note: Section 101.149 (8), Stats., reads:

(8) PENALTIES. (a) If the department of commerce or the department of health services determines after an inspection of a building under this section or s. 254.74 (1g) that the owner of the building has violated sub. (2) or (3), the respective department shall issue an order requiring the person to correct the violation within 5 days or within such shorter period as the respective department determines is necessary to protect public health and safety. If the person does not correct the violation within the time required, he or she shall forfeit \$50 for each day of violation occurring after the date on which the respective department finds that the violation was not corrected.

(b) If a person is charged with more than one violation of sub. (2) or (3) arising out of an inspection of a building owned by that person, those violations shall be counted as a single violation for the purpose of determining the amount of a forfeiture under par. (a).

(c) Whoever violates sub. (4) is subject to the following penalties:

- 1. For a first offense, the person may be fined not more than \$10,000 or imprisoned for not more than 9 months, or both.**
- 2. For a 2nd or subsequent offense, the person is guilty of a Class I felony.**

INSERT PAGES
IBC CHAPTER 13

There are no insert pages for Chapter 13

INSERT PAGES
IBC CHAPTER 14

To be inserted between pages 258 & 259.

Comm 62.1405 Wall coverings. (1) EXTERIOR WINDOWS AND DOORS. The requirements in IBC section 1405.12 are not included as part of this code.

(2) POLYSTYRENE SHEATHING. This is a department rule in addition to the requirements in IBC section 1405.13.1:

(a) Extruded polystyrene sheathing having all of the characteristics in [par. \(b\)](#) may be utilized as the required backing material for vinyl siding when used in accordance with all of the limitations in [par. \(c\)](#).

(b) 1. Extruded, rigid, and cellular.

2. Type IV, as specified in ASTM C 578.

3. Thickness of at least one inch.

(c) 1. On-center stud spacing of 16 inches or less.

2. Mean roof height of 40 feet or less.

3. Wind exposure category of B, or C, as established in IBC section 1609.4; and the building is not sited on the upper half of an isolated hill or escarpment meeting conditions 1, 2, and 3 in IBC section 1609.1.1.1.

INSERT PAGES
IBC CHAPTER 14

To be inserted between pages 260 & 261.

Comm 62.1407 Metal composite materials. (1) APPROVAL. Substitute the following wording for the requirements in IBC section 1407.5: Results of approved tests or an engineering analysis shall be made available to the code official upon request to verify compliance with the requirements of IBC chapter 16 for wind loads.

(2) FIRE-RESISTANCE RATING. Substitute the following wording for the requirements in IBC section 1407.8: Where MCM systems are used on exterior walls required to have a fire-resistance rating in accordance with IBC section 704, evidence shall be made available to the code official upon request that the required fire-resistance rating is maintained.

(3) LABELING. The requirements in IBC section 1407.13 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 15

To be inserted between pages 264 & 265.

Comm 62.1505 Roof covering classification. The requirements in Footnote a in IBC Table 1505.1. are not included as part of this code.

Comm 62.1506 Roof covering materials. Substitute the following wording for the requirements in IBC section 1506.3: Roof covering materials shall conform to the applicable standards listed in IBC chapter 15.

INSERT PAGES
IBC CHAPTER 15

To be inserted between pages 274 & 275.

Comm 62.1507 Roof slope. (1) This is a department exception to the requirements in IBC section 1507.12.1: Thermoset single-ply membrane roofs may have a design slope of less than 2 percent, if permitted by the manufacturer's literature or listing criteria.

(2) This is a department exception to the requirements in IBC section 1507.13.1: Thermoplastic single-ply membrane roofs may have a design slope of less than 2 percent, if permitted by the manufacturer's literature or listing criteria.

(3) This is a department exception to the requirements in IBC section 1507.14.1: Sprayed polyurethane foam roofs may have a design slope of less than 2 percent, if permitted by the manufacturer's literature or listing criteria.

(4) This is a department exception to the requirements in IBC section 1507.15.1: Liquid-applied roofs may have a design slope of less than 2 percent, if permitted by the manufacturer's literature or listing criteria.

INSERT PAGES
IBC CHAPTER 16

To be inserted between pages 278 & 279.

Comm 62.1603 Construction documents. (1) FLOOD DESIGN DATA. Item 5 under the exception in IBC section 1603.1 is not included as part of this code.

(2) ROOF SNOW LOAD. Substitute the following wording for the requirements in IBC section 1603.1.3: The ground snow load, P_g , shall be indicated. In areas where the ground snow load, P_g , exceeds 10 pounds per square foot, the following additional information shall also be provided, regardless of whether snow loads govern the design of the roof:

- (a) Flat-roof snow load, P_f
- (b) Snow exposure factor, C_e .
- (c) Snow load importance factor, I .
- (d) Thermal factor, C_t .
- (e) Any sloped-roof snow load, P_s .
- (f) Any unbalanced, drift or sliding snow loads.

(3) FLOOD DESIGN. The requirements in IBC section 1603.1.6 are not included as part of this code.

(4) SPECIAL INSTRUCTIONS. The requirements in IBC section 1603.1.8 are not included as part of this code.

(5) LIVE LOADS POSTED. Substitute the following wording for the requirements in IBC section 1603.3: Where the live loads for which each floor or portion thereof of a commercial or industrial building is or has been designed to exceed 100 pounds per square foot, such design live loads shall be conspicuously posted by the owner in that part of each story in which they apply, using durable signs. It shall be unlawful to remove or deface such notices.

(6) OCCUPANCY PERMITS. The requirements in IBC section 1603.4 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 16

To be inserted between pages 280 & 281.

Comm 62.1604 Alternate evaluations. (1) IN-SITU LOAD TESTS. Substitute the following wording for the requirements in IBC section 1604.6: The building official is authorized to require an engineering analysis or a load test, or both, of any construction whenever there is reason to question the safety of the construction for the intended occupancy.

(2) ALTERNATE APPROVALS. Substitute the following wording for the requirements in IBC section 1604.7: Materials and methods of construction that are not capable of being designed by approved engineering analysis or that do not comply with the applicable material design standards listed in IBC chapter 35 shall be submitted for approval in accordance with subch. V of ch. Comm 61.

INSERT PAGES
IBC CHAPTER 16

To be inserted between pages 284 & 285.

Comm 62.1607 Live loads. (1) RESIDENTIAL FLOOR LOADS. Substitute the following wording and live loads for the requirements in line 28 and footnote j of IBC Table 1607.1:

Table 1607.1
Minimum Uniformly Distributed Live Loads
and Minimum Concentrated Live Loads^g
(Partial Table)

Occupancy or Use	Uniform (psf)	Concentrated (lbs.)
28. Residential		
Three or more attached dwelling units not more than 3 stories high, with separate means of egress for each unit		
Uninhabitable attics without storage ⁱ	5	
Uninhabitable attics with storage ^{i, j, k}	20	—
All other areas except balconies	40	
Hotels and Group R-2		
Private rooms and corridors serving them	40	
Public rooms and corridors serving them	100	

j. For attics with storage and constructed with trusses, this live load need only be applied to those portions of the bottom chord where there are two or more adjacent trusses with the same web configuration capable of containing a rectangle 42 inches high by 2 feet wide or greater, located within the plane of the truss. The rectangle shall fit between the top of the bottom chord and the bottom of any other truss member, provided that each of the following criteria is met:

- i. The attic area is accessible by a pull-down stairway or framed opening in accordance with Section 1209.2, and
- ii. The truss shall have a bottom chord pitch less than 2:12.
- iii. Bottom chords of trusses shall be designed for the greater of actual imposed dead load or 10 psf, uniformly distributed over the entire span.

(2) CONCENTRATED LOADS. Substitute the following wording for the requirements in IBC section 1607.4: Floors and other similar surfaces shall be designed to support the uniformly distributed live loads prescribed in IBC section 1607.3 or the concentrated load, in pounds, given in IBC Table 1607.1, whichever produces the greater load effects. Unless otherwise specified, the indicated concentration shall be assumed to be uniformly distributed over an area 2.5 feet by 2.5 feet and shall be located so as to produce the maximum load effects in the structural members.

(3) TRUCK AND BUS GARAGES. Substitute the following wording for the requirements in IBC section 1607.6: Minimum live loads for garages having trucks or buses shall be as specified in IBC Table 1607.6, but shall not be less than 50 pounds per square foot. Actual loads shall be used where they are greater than the loads specified in the table.

INSERT PAGES
IBC CHAPTER 16

To be inserted between pages 288 & 289.

Comm 62.1608 Snow loads. (1) UNBALANCED SNOW LOADS. This is a department alternative to the requirements in IBC section 1608.1: Unbalanced snow loads on a hip or gable roof may be calculated in accordance with the following equation:

$$S = S_s(I_s)(C_b C_w C_s C_a)$$

Where:

S = Alternate unbalanced roof snow load

S_s = Ground snow load from IBC Figure 1608.2

I_s = Importance factor from IBC Table 1608.1 [ASCE 7, Table 7-4]

C_b = Basic roof snow load factor of 0.8

C_w = Wind exposure factor of 1.0

C_s = Slope factor; see Tables 62.1608-1 and 62.1608-2

C_a = Accumulation factor; see Table 62.1608-3

Table 62.1608-1
Non-Slippery Roof^a

Roof Slope, α Factor, C_s

$\alpha < 30^\circ$ 1.0

$30^\circ < \alpha < 70^\circ$ $(70^\circ - \alpha) / 40^\circ$

$70^\circ < \alpha$ 0

^a Such as with shingles.

INSERT PAGES
IBC CHAPTER 16

Table 62.1608-2
Unobstructed Slippery Roofs

Roof Slope, α	Factor, C_s
$\alpha < 15^\circ$	1.0
$15^\circ < \alpha < 60^\circ$	$(60^\circ - \alpha) / 45^\circ$
$60^\circ < \alpha$	0

a Where snow and ice can slide completely off, such as with steel.

Table 62.1608-3
Accumulation Factor

Roof Slope, α	Factor, C_a
$\alpha < 15^\circ$	N/A. Analysis for balanced loading only.
$15^\circ < \alpha < 20^\circ$	$0.25 + \alpha / 20^\circ$
$20^\circ < \alpha < 90^\circ$	1.25

Comm 62.1608 Snow loads. (2) EXISTING ROOFS. These are department rules in addition to the requirements in IBC section 1608.1:

(a) *Buildings on the same property.*

1. Where an existing roof, regardless of the date of its construction, is horizontally within 15 feet of a proposed, taller structure on the same property, IBC section 1608.1 or an alternate recognized engineering method shall be applied to the existing roof, to address any drifting or sliding of snow onto the existing roof, as caused by the taller structure.

2. Where an analysis under subd. 1. shows that an existing roof or corresponding supporting elements will not be adequate to support the additional snow load caused by the taller structure, the existing roof or supporting elements shall be strengthened to support those loads, in accordance with this code.

(b) *Buildings on adjoining properties.* Where an existing roof, regardless of the date of its construction, is horizontally within 15 feet of a proposed, taller structure on an adjoining property, the owner of the proposed structure shall notify the adjoining owner of the potential for increased structural loads on the existing roof, due to sliding or drifting of snow, as caused by the taller structure.

INSERT PAGES
IBC CHAPTER 16

To be inserted between pages 298 & 299.

Comm 62.1611 Roof drains. This is a department informational note to be used under IBC section 1611.1:

Note: See ch. Comm 82 for requirements to not connect a secondary roof-drain system to a primary roof-drain system, and to discharge a secondary roof-drain system to the ground surface.

INSERT PAGES
IBC CHAPTER 16

To be inserted between pages 300 & 301.

Comm 62.1612 Flood loads. The requirements in IBC section 1612 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 16

To be inserted between pages 302 & 303.

Comm 62.1613 Earthquake loads. (1) Exception 1 in IBC section 1613.1 is not included as part of this code.

(2) The requirements in IBC section 1613.4 are not included as part of this code.

(3) This is a department informational note to be used under IBC section 1613.5:

Note: An interactive Web site maintained by the U. S. Geological Service, at <http://eqint.cr.usgs.gov/eq-men/html/zipcode-06.html>, can be used in lieu of IBC Figures 1613.5 (1) and (2) to determine the spectral response acceleration values for an inputted zip-code area.

INSERT PAGES
IBC CHAPTER 17

To be inserted between pages 326 & 327.

Comm 62.1700 Structural tests and special inspections. The requirements in IBC chapter 17, except for the requirements in IBC sections 1710 to 1715, are not included as part of this code.

INSERT PAGES
IBC CHAPTER 18

To be inserted between pages 342 & 343.

Comm 62.1802 Foundation and soil investigation. (1) GENERAL. Substitute the following wording for the requirements in IBC section 1802.1: Foundation and soils investigations shall be conducted in conformance with IBC sections 1802.2 through 1802.6.

(2) WHERE REQUIRED. Substitute the following wording for the requirements, but not the exception, in IBC section 1802.2: The owner or applicant shall make a foundation and soils investigation available to the building official, upon request, where required in IBC sections 1802.2.1 through 1802.2.7.

(3) QUESTIONABLE SOIL. Substitute the following wording for the requirements in IBC section 1802.2.1: Where the classification, strength or compressibility of the soil is in doubt, or where a load-bearing value superior to that specified in this code is claimed, an investigation complying with the provisions of IBC sections 1802.4 through 1802.6 shall be made.

(4) EXPANSIVE SOILS. Substitute the following wording for the requirements in IBC section 1802.2.2: In areas likely to have expansive soil, soil tests shall be conducted to determine where such soils do exist.

INSERT PAGES
IBC CHAPTER 18

To be inserted between pages 344 & 345.

Comm 62.1803 Grading and fill in flood hazard areas. The requirements in IBC section 1803.4 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 18

To be inserted between pages 346 & 347.

Comm 62.1805 Footings and foundations. (1) ALTERNATE SETBACK AND CLEARANCE. Substitute the following wording for the requirements in IBC section 1805.3.5: Alternate setbacks and clearances are permitted, subject to the approval of the building official.

INSERT PAGES
IBC CHAPTER 18

To be inserted between pages 354 & 355.

Comm 62.1805 Footings and foundations. (2) SHALLOW POST FOUNDATIONS.
This is a department alternative to the requirements in IBC section 1805.7.2: The design criteria in ANSI/ASAE EP486.1 may be used in lieu of the design criteria in IBC section 1805.7.2. following limitations apply:

INSERT PAGES
IBC CHAPTER 18

To be inserted between pages 356 & 357.

Comm 62.1807 Flood hazard areas. The requirements in IBC section 1807.1.2.1 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 18

To be inserted between pages 358 & 359.

Comm 62.1808 Pier and pile foundations. (1) DEFINITION OF NEUTRAL PLANE.

This is a department definition in addition to the definitions in IBC section 1808.1:
NEUTRAL PLANE. A pile's neutral plane is the level at which drag load, accumulated from the top down, added to the long-term static service load, equals the upward acting shaft resistance accumulated from the bottom up, added to the pile's toe resistance.

(2) DOWNDRAG. This is a department rule in addition to the requirements in IBC section 1808.2.1: Investigations and reports for pier or pile foundations shall include analysis of whether downdrag is anticipated. Where downdrag is anticipated, the report shall include a determination of the position of the pile's neutral plane, an estimate of the soil settlement at the neutral plane, and a determination of the maximum load at the neutral plane.

To be inserted between pages 360 & 361.

Comm 62.1808 Pier and pile foundations. (3) DETERMINATION OF ALLOWABLE LOADS. Substitute the following wording for the requirements in IBC section

1808.2.8.1:

- (a) The allowable axial and lateral loads on piers or piles shall be determined by an approved formula, load tests or static analysis.
- (b) The factor of safety to be used for pier or pile design shall depend on the extent of field testing performed to verify capacity.
- (c) If the ultimate capacity is assessed solely by static analysis, a minimum factor of safety of 3.0 shall be applied to the ultimate capacity to determine allowable load capacity.
- (d) If only static analysis and dynamic field testing are performed, a minimum factor of safety of 2.5 shall be applied to the ultimate capacity to determine load capacity.
- (e) If one or more static load tests are performed, in addition to a static analysis, a minimum factor of safety of 2.0 shall be applied to the ultimate allowable capacity.
- (f) A minimum factor of safety of 2.0 shall be used for occupiable structures provided that all of the conditions in pars. (a) to (e) are met. A minimum factor of safety of 1.5 may be used for non-occupiable structures, provided that the deep foundations are required only to control settlement, and it can be demonstrated that deep foundations are not required to prevent a bearing capacity failure.

(4) LOAD TESTS. This is a department alternative to the requirements in IBC section 1808.2.8.3: The ultimate capacity of the pile shall be defined as the load at which the average pile head deflection is defined by the following equation:

$$\delta = (Pl/AE) + 0.15" + (B/120)$$

Where:

δ = average pile head deflection, inches

P = applied load, pounds

l = pile length, inches

A = transformed pile area of pile (to steel)

E = modulus of elasticity (of steel)

B = outside diameter (or width) of pile, inches

The calculation shall be predicated on an assumed end-bearing condition.

Comm 62.1808 Pier and pile foundations. (5) PILES IN SUBSIDING AREAS.

Substitute the following wording for the requirements in IBC section 1808.2.11:

- (a) Where piles are installed through subsiding fills or other subsiding strata and derive support from underlying firmer materials, consideration shall be given to the downward drag load that may be imposed on the piles by the subsiding upper strata.
- (b) Where the influence of subsiding fills is considered as imposing loads on the pile, the allowable stresses specified in this chapter are permitted to be increased where satisfactory substantiating data are submitted.
- (c) The position of the pile's neutral plane shall be determined, and the settlement of the soil at the level of the neutral plane shall be estimated. The maximum load in the pile, which occurs at the neutral plane, shall be determined.

(6) SPECIAL INSPECTION. The requirements in IBC section 1808.2.22 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 18

To be inserted between pages 362 & 363.

Comm 62.1809 Driven pile foundations. Substitute the following wording for the requirements in IBC section 1809.1.3: Any substantial sudden increase in rate of penetration of a timber pile shall be investigated for possible damage. If the sudden increase in rate of penetration cannot be correlated to soil strata, the pile shall be removed for inspection or rejected, or shall be assigned a reduced capacity commensurate with the loss of end-bearing in lieu of removing or rejecting the pile.

INSERT PAGES
IBC CHAPTER 18

To be inserted between pages 366 & 367.

Comm 62.1810 Concrete pile foundations. (1) DIMENSIONS FOR DRILLED OR AUGERED UNCASSED PILES. Substitute the following wording for the exception in IBC section 1810.3.2: The length of the pile is permitted to exceed 30 times the diameter, provided that the design and installation of the pile foundation is under the direct supervision of a registered design professional knowledgeable in the field of soil mechanics and pile foundations.

(2) DIMENSIONS FOR DRIVEN UNCASSED PILES. Substitute the following wording for the exception in IBC section 1810.4.2: The length of the pile is permitted to exceed 30 times the diameter, provided that the design and installation of the pile foundation is under the direct supervision of a registered design professional knowledgeable in the field of soil mechanics and pile foundations.

INSERT PAGES
IBC CHAPTER 19

To be inserted between pages 372 & 373.

Comm 62.1901 General requirements for concrete. (1) CONSTRUCTION DOCUMENTS. The requirements in IBC section 1901.4 are not included as part of this code.

(2) SPECIAL INSPECTION. The requirements in IBC section 1901.5 are not included as part of this code.

Comm 62.1903 Specifications for concrete. Substitute the following wording for the requirements in IBC section 1903.1: Materials used to produce concrete, concrete itself and testing thereof shall comply with the applicable standards listed in ACI 318.

INSERT PAGES
IBC CHAPTER 19

To be inserted between pages 378 & 379.

Comm 62.1908 Deletions. (1) Exception (a) in IBC section 1908.1.15 is not included as part of this code.

(2) The exception under (b) in IBC section 1908.1.15 is not included as part of this code.

(3) Exception 1 under (c) in IBC section 1908.1.15 is not included as part of this code.

INSERT PAGES
IBC CHAPTER 19

To be inserted between pages 380 & 381.

Comm 62.1913 Shotcrete clearance. The exception in IBC section 1913.4.2 is not included as part of this code.

INSERT PAGES
IBC CHAPTER 19

To be inserted between pages 382 & 383.

Comm 62.1915 Column approvals. Substitute the following wording for the requirements in IBC section 1915.6.: Details of column connections and splices shall be shop-fabricated by approved methods and testing. Shop-fabricated concrete-filled pipe columns shall be inspected by a representative of the manufacturer at the plant.

INSERT PAGES
IBC CHAPTER 20

There are no modifications to Chapter 20.

INSERT PAGES
IBC CHAPTER 21

To be inserted between pages 386 & 387.

Comm 62.2101 Masonry construction materials. (1) PRESTRESSED MASONRY.

Substitute the following wording for the requirements in IBC section 2101.2.3:

Prestressed masonry shall be designed in accordance with chapters 1 and 4 of ACI 530/ASCE 5/TMS 402 and IBC section 2106.

(2) CONSTRUCTION DOCUMENTS. The requirements in IBC section 2101.3 are not included as part of this code.

(3) FIREPLACE DRAWINGS. The requirements in IBC section 2101.3.1 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 21

To be inserted between pages 390 & 391.

Comm 62.2103 Cast stone masonry units. These are department rules in addition to the requirements in IBC section 2103.4:

- (1) Cast stone masonry units covered under this category are homogeneous or faced, dry cast concrete products other than conventional concrete masonry units (brick or block), but of similar size.
- (2) Cast stone masonry units shall be made with portland cement, water and suitable mineral aggregates, with or without admixtures, and reinforced if required.
- (3) Cast stone masonry units shall have a minimum compressive strength of 6500 psi and a maximum water absorption of 6% when tested as 2- x 2-inch cylinders or cubes.

INSERT PAGES
IBC CHAPTER 21

To be inserted between pages 396 & 397.

Comm 62.2105 Masonry quality. The requirements in IBC section 2105.1 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 21

To be inserted between pages 400 & 401.

Comm 62.2109 Empirical design of masonry. (1) BEARING ON MASONRY. This is a department rule in addition to the requirements in IBC section 2109.1: Lintels shall be considered structural members and shall be designed in accordance with the applicable provisions of IBC chapter 16.

INSERT PAGES
IBC CHAPTER 21

To be inserted between pages 402 & 403.

Comm 62.2109 Empirical design of masonry. (2) OPENINGS. This is a department rule in addition to the requirements in IBC section 2109.4.1: Unless evidence is provided to show that openings do not cause lateral stability and stress requirements to be exceeded, the amount of openings in a masonry wall shall not exceed the limits set forth in Table 62.2109-1.

Table 62.2109-1
Maximum Ratio of Laterally Unsupported Height or
Length to Thickness for Exterior Walls With Openings†

Type of Masonry	Percent of Openings at Any Horizontal Plane of Wall			
	20	40	60	Over 60
Single wythe walls of solid or grouted walls of solid units	20	16	12	Submit design
All other masonry	18	14	10	calculations

†The percentage of openings shall be calculated for each 100 lineal feet of wall or portion thereof at any horizontal plane of wall.

Comm 62.2109 Empirical design of masonry. (3) JOINTING. These are department rules in addition to the requirements in IBC section 2109:

(a) *Expansion and shrinkage.* Joints commensurate with lateral stability requirements shall be installed in all exterior masonry to allow for expected growth of clay products and shrinkage of concrete products.

(b) *Vertical jointing.* Vertical movement joints shall be provided at a spacing in compliance with Table 62.2109-2.

Table 62.2109-2
Maximum Spacing Of Exterior Masonry Movement Joints
Between Unrestrained Ends† (Feet)

Loading Conditions	Type of Material	Openings (Percent of Total Wall Area)			
		0 to 20		More than 20	
		Joint to Joint	Joint to Corner	Joint to Joint	Joint to Corner
Load-bearing	Clay units	140	70	100	50
	Concrete units	60	30	40	20
Nonload-bearing walls	Clay units	100	50	60	40
	Concrete units	50	25	30	20

†Jointing required is a minimum and is not intended to prevent minor cracking. The distances given for maximum spacing of joints are for a single wall plane. For composite walls, the maximum spacing of joints shall be governed by the masonry material type used in the exterior wythe.

Note: To accomplish the intended purpose, joints should be located at critical locations, such as changes in building heights, changes in framing systems, columns built into exterior walls, major wall openings, and changes in materials.

(c) *Horizontal jointing.* Where supports such as shelf angles or plates are required to carry the weight of masonry above the foundation level, a pressure-relieving joint shall be provided between the structural support and any masonry that occurs below this level. The joint width shall be such as to prevent any load being transmitted from the support to any element directly below. All mortar and rigid materials shall be kept out of this joint. This type of joint shall be provided at all such supports in a concrete frame structure where clay masonry is exposed to the weather.

INSERT PAGES
IBC CHAPTER 22

To be inserted between pages 416 & 417.

Comm 62.2204 Connections. (1) WELDING. Substitute the following wording and informational note for the requirements in IBC section 2204.1: The details of design, workmanship and technique for welding, inspection of welding, and qualifications of welding operators shall conform to the requirements of the specifications listed in IBC sections 2205, 2206, 2207, 2209 and 2210.

Note: The rules pertaining to registration of structural welders are specified in ch. Comm 5.

(2) BOLTS. Substitute the following wording for the requirements in IBC section 2204.2: The design, installation and inspection of bolts shall be in accordance with the requirements of the specifications listed in IBC sections 2205, 2206, 2209 and 2210.

INSERT PAGES
IBC CHAPTER 22

To be inserted between pages 418 & 419.

Comm 62.2206 The requirements in IBC sections 2206.3 to 2206.5 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 23

To be inserted between pages 424 & 425.

Comm 62.2303 (1) LABELING. Substitute the following wording for the requirements in IBC section 2303.2.1: The identification mark of an approved agency.

(2) TRUSS DESIGN DRAWINGS. The requirements in IBC section 2303.4.1.2 to 2303.4.1.4 are not included as part of this code.

Comm 62.2303 (3) TRUSSES. Substitute the following wording for the requirements in IBC section 2303.4.2: In addition to IBC sections 2303.4.1, 2303.4.1.1 and 2303.4.1.5 through 2303.4.1.7, the design, manufacture and quality assurance of metal-plate-connected wood trusses shall be in accordance with TPI 1.

INSERT PAGES
IBC CHAPTER 23

To be inserted between pages 434 & 435.

Comm 62.2304 Girder ends. This is a department rule in addition to the requirements in IBC section 2304.11.2.5: A moisture barrier shall be provided between an untreated or nondurable wood girder and an exterior masonry or concrete bearing surface.

INSERT PAGES
IBC CHAPTER 24

To be inserted between pages 500 & 501.

Comm 62.2409 Glass and glazing for elevators. This is a department informational note to be used under IBC section 2409:

Note: See ch. Comm 18 [ASME A17.1] for additional glass and glazing requirements relating to elevators. Those requirements include a prohibition against elevator hoistway windows that give a false appearance of a floor level.

INSERT PAGES
IBC CHAPTER 25

To be inserted between pages 500 & 501.

Comm 62.2503 Gypsum board and plaster. The requirements in IBC section 2503.1 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 26

There are no modifications to Chapter 26.

INSERT PAGES
IBC CHAPTER 27

To be inserted between pages 516 & 517.

Comm 62.2701 Electrical code. This is a department informational note to be used under IBC section 2701.1:

Note: As defined in s. Comm 61.04 (6), "ICC Electrical Code" means ch. Comm 16.

INSERT PAGES
IBC CHAPTER 28

There are no modifications to Chapter 28

To be inserted between pages 520 & 521.

Comm 62.2900 Additional criteria for plumbing fixtures. These are department rules in addition to the requirements in IBC chapter 29.

(1) PLUMBING FIXTURE ALTERNATIVES. (a) *Water closets.* Systems or devices recognized under ch. Comm 91 may be substituted for water closets required under IBC chapter 29.

(b) *Lavatories.* Waterless antiseptic cleansing provisions may be substituted for lavatories required under IBC chapter 29.

(2) PERMANENT OUTDOOR TOILETS. (a) A permanent outdoor toilet room shall be provided with a suitable approach such as a concrete, gravel or cinder walk.

(b) All windows, ventilators, and other openings for a permanent outdoor toilet room shall be screened to limit the entrance of flies, and all doors shall be self closing.

(3) ENCLOSURE OF FIXTURES. (a) Water closets and urinals within a toilet room shall be arranged to ensure privacy. Except as provided in par. (b), each water closet shall occupy a separate compartment with walls or partitions and a door enclosing the fixtures to ensure privacy. Urinals shall be placed against walls at least 6 feet 8 inches high and arranged individually with or without partitions.

(b) 1. Water closet compartments may be omitted in a single-occupant toilet room having a door with a privacy lock.

2. Toilet rooms located in day-care and child-care facilities and containing 2 or more water closets may have one water closet without an enclosing compartment.

3. Compartments are not required for water closets in prison or jail cells.

Comm 62.2901 Plumbing code. This is a department informational note to be used under IBC section 2901.1:

Note: As defined in s. Comm 61.04 (12) and (13), "IPC and International Plumbing Code" and "IPSC and International Private Sewage Code" mean chs. Comm 81 to 87.

Comm 62.2902 Plumbing fixtures. (1) MINIMUM NUMBER OF FIXTURES.

(a) *Exceptions.* These are department exceptions to the requirements in IBC section 2902.1:

1. Where more than one water closet is required for males, urinals may be substituted for up to 50 percent of the required number of water closets.

2. Where water is served in restaurants or where other acceptable arrangements are made to provide drinking water, drinking fountains are not required.

3. For child day care facilities, bathtubs or showers are not required where other personal hygiene washing arrangements are provided that satisfy the licensing requirements of the Wisconsin department of health and family services.

4. For day nurseries and child day care facilities, children under the age of 30 months need not be considered as a part of the occupant load used to determine the minimum number of water closets.

Comm 62.2902 Plumbing fixtures. (b) *Additional fixtures.* These are department informational notes to be used under IBC sections 2902.1 and 2902.2:

Note: Additional plumbing fixtures may be required for employees by the U.S. department of labor, occupational safety and health act (OSHA) regulations.

Note: Additional plumbing fixtures may be required by the department of health and family services for restaurants, mobile home parks, camping grounds, camping resorts, recreational camps and educational camps.

Note: Chapter Comm 90 also has requirements for minimum numbers of sanitary fixtures for a public swimming pool, as based on the pool area. For some buildings, the minimum number of sanitary fixtures determined in that manner may be larger than the minimum number determined in accordance with this section. Compliance with this section does not relieve an owner from complying with ch. Comm 90.

Note: Chapter Comm 91 has requirements for equal speed of access to toilets for each gender, at facilities where the public congregates that do not fall under the scope of this chapter.

(c) *Substitutions in IBC Table 2902.1.*

1. Substitute the following wording for the water closets heading in IBC Table 2902.1: Water closets^e (see s. Comm 62.2902 (1) (a) 1. for urinals).

2. Substitute the following wording for the drinking fountains heading in IBC Table 2902.1: Drinking fountains (see s. Comm 62.2902 (1) (a) 2.).

3. In IBC Table 2902.1, substitute the following wording for the required minimum number of water closets for females in type A-4 and A-5 occupancies: 1 per 37 for the first 1,500 and 1 per 60 for the remainder exceeding 1,500.

4. Substitute the following wording for the required number of bathtubs or showers in storage occupancies in IBC Table 2902.1: See the International Plumbing Code.

5. Substitute the following wording for the required number of bathtubs or showers in factory and industrial occupancies in IBC Table 2902.1: See the International Plumbing Code.

(d) *Addition to IBC Table 2902.1.* This is an additional department footnote for IBC Table 2902.1: Footnote e. Wherever more than 500 people congregate and more than the required minimum number of water closets or urinals are provided for males, twice as many of those additional toilet facilities shall be provided for females.

(2) LAVATORIES FOR TOILET ROOMS. This is a department rule in addition to the requirements in IBC section 2902.1: At least one lavatory shall be provided in each toilet room or in a gender-designated lounge adjacent to the toilet room. If a multiple-use lavatory is provided, 24 lineal inches of wash sink, or 20 inches measured along the edge of a circular basin will be considered equivalent to one lavatory.

INSERT PAGES
IBC CHAPTER 29

To be inserted between pages 522 & 523.

Comm 62.2902 Plumbing fixtures. (3) DISTRIBUTION OF PLUMBING FACILITIES AND NUMBER OF OCCUPANTS OF EACH SEX. Substitute the following wording for the requirements in IBC section 2902.3: Except as otherwise specified in IBC Table 2902.1, the required water closets, lavatories, and showers or bathtubs shall be distributed equally between the sexes based on the percentage of each sex anticipated in the occupant load. The occupant load shall be composed of 50 % of each sex, unless statistical data approved by the code official indicate a different distribution of the sexes.

(4) PUBLIC FACILITIES. This is a department exception to the requirements in IBC section 2902.4: Toilet rooms may be omitted in a small retail or mercantile building where all of the following requirements are met:

- (a) No more than 25 occupants are accommodated.
- (b) Other restrooms are conveniently located and available to the patrons and employees during all hours of operation.
- (c) The omission is approved in writing by the local unit of government.
- (d) A copy of the written approval from the local unit of government is provided to the department or its authorized representative upon request.

(5) LOCATION OF RESTAURANT TOILET ROOMS. This is a department informational note to be used under IBC section 2902.4:

Note: Additional location requirements for restaurant toilet rooms may be applied by the department of health and family services.

INSERT PAGES
IBC CHAPTER 29

To be inserted between pages 524 & 525

Comm 62.2902 Plumbing fixtures. (6) PAY FACILITIES. Substitute the following wording for the requirements in IBC section 2902.4.3: All toilet facilities shall be free of charge.

Note: Section 146.085, Stats., prohibits charging a fee for the use of toilet facilities and imposes a fine of \$10 to \$50 for violations.

INSERT PAGES
IBC CHAPTER 30

To be inserted between pages 524 & 525.

Comm 62.3001 Elevators. (1) SCOPE. Substitute the following wording for the requirements in IBC section 3001.1: This chapter governs the design, construction, installation, alteration and repair of elevators, dumbwaiters, escalators, moving walks and their components.

(2) REFERENCED STANDARDS. Substitute the following wording for the requirements in IBC section 3001.2: Except as otherwise provided for in this code, the design, construction, installation, alteration, repair and maintenance of elevators, dumbwaiters, escalators, moving walks and their components shall comply with ch. Comm 18.

(3) CHANGE IN USE. Substitute the following wording for the requirements in IBC section 3001.4: A change in use of an elevator from freight to passenger, passenger to freight, or from one freight class to another freight class shall comply with ch Comm 18.

To be inserted between pages 526 & 527.

Comm 62.3004 Hoistways. (1) VENTING. This is a department rule in addition to the requirements in IBC section 3004.3: A ventilation opening in a hoistway wall, where provided, shall have guards securely anchored to the supporting structure inside the hoistway. The guards shall consist of a wire-mesh screen of at least 0.0915-inch diameter steel wire with openings that will reject a ball one-inch in diameter, or expanded metal screen of equivalent strength and open area.

(2) PLUMBING AND MECHANICAL SYSTEMS. Substitute the following wording for the requirements and the exception in IBC section 3004.4:

(a) *General.* Except as specified in [par. \(b\)](#), plumbing and mechanical systems shall not be located in an elevator shaft.

(b) *Elevator pits.* Drains or sumps complying with [ss. Comm 82.33](#) and [82.36](#) shall be provided in elevator pits. Connection of these drains and sumps to a sanitary system is prohibited.

Comm 62.3006 Machine rooms. (1) ACCESS. This is a department informational note to be used under IBC section 3006.1:

Note: See ch. Comm 18 for additional machine room access requirements. Those requirements include a prohibition against accessing an elevator machine room through a toilet room, sleeping room or private space; and a prohibition against accessing other spaces in a building through an elevator machine room.

(2) PRESSURIZATION. This is a department exception to the requirements in IBC section 3006.3: An elevator machine room which serves a pressurized elevator hoistway and which is not directly connected to the pressurized elevator shaft is not required to be pressurized.

(3) SHUNT TRIP. Substitute the following wording for the requirements in IBC section 3006.5: Where elevator hoistways or elevator machine rooms containing elevator control equipment are protected with automatic sprinklers, a means installed in accordance with NFPA 72, section 6.15.4, Elevator Shutdown, shall be provided to disconnect automatically the main line power supply to the affected elevator prior to the application of water. This means shall not be self-resetting. The activation of sprinklers outside the hoistway or machine room shall not disconnect the main line power supply.

(4) PLUMBING SYSTEMS. Substitute the following wording for the requirements in IBC section 3006.6: Plumbing systems not used in connection with the operation of the elevator may not be located in elevator equipment rooms.

INSERT PAGES
IBC CHAPTER 31

To be inserted between pages 528 & 529.

Comm 62.3100 Special construction. This department rule is in addition to the requirements in IBC chapter 31:

PUBLIC MAUSOLEUMS. Public mausoleum structures shall be designed, constructed and maintained in accordance with this code. Mausoleums shall be classified as a Group S-1 storage occupancy and shall be constructed of reinforced concrete or other materials of similar durability.

Note: Section 157.12 (2) (d), Stats., reads as follows: "A mausoleum shall be constructed to last as long as possible, taking into consideration the technology and economics applicable to mausoleum construction at the time of construction."

INSERT PAGES
IBC CHAPTER 31

To be inserted between pages 530 & 531.

Comm 62.3102 Blower equipment. Substitute the following wording for requirement 2 in IBC section 3102.8.1.2: Blowers shall be provided with inlet screens, belt guards and other protective devices as required to provide protection from injury.

Comm 62.3103 Temporary structures. This is a department rule in addition to the requirements in IBC section 3103: Under IBC sections 3103.1.1 and 3103.2, the requirements for permits and construction documents for temporary structures are at the option of the local code official.

Comm 62.3104 Pedestrian walkways and tunnels. Substitute the following wording for the requirements and exception in IBC section 3104.2: Buildings that are connected in accordance with IBC section 3104 shall be considered to be separate structures.

INSERT PAGES
IBC CHAPTER 31

To be inserted between pages 532 & 533.

Comm 62.3109 Swimming pool enclosures. Substitute the following informational note for the requirements in IBC section 3109.

Note: See ch. Comm 90 for requirements for swimming pool enclosures.

INSERT PAGES
IBC CHAPTER 32

To be inserted between pages 534 & 535.

Comm 62.3200 Encroachments into the public right-of-way. The requirements in IBC chapter 32 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 33

To be inserted between pages 536 & 537.

Comm 62.3300 Safeguards during construction. Except for the requirements in IBC sections 3302.1 and 3303.5, the requirements in IBC chapter 33 are not included as part of this code.

To be inserted between pages 538 & 539.

Comm 62.3307 Protection of adjoining property. This is a department informational note to be used under IBC chapter 33:

Note: Sections 101.111 (1) to (6), Stats., read as follows:

"(1) DEFINITION. In this section `excavator' means any owner of an interest in land making or causing to be made an excavation.

(2) CAVE-IN-PREVENTION. Any excavator shall protect the excavation site in such a manner so as to prevent the soil of adjoining property from caving in or settling.

(3) LIABILITY FOR UNDERPINNING AND FOUNDATION EXTENSIONS. (a) If the excavation is made to a depth of 12 feet or less below grade, the excavator may not be held liable for the expense of any necessary underpinning or extension of the foundations of buildings on adjoining properties.

(b) If the excavation is made to a depth in excess of 12 feet below grade, the excavator shall be liable for the expense of any necessary underpinning or extension of the foundations of any adjoining buildings below the depth of 12 feet below grade. The owners of adjoining buildings shall be liable for the expense of any necessary underpinning or extension of the foundations of their buildings to the depth of 12 feet below grade.

(4) NOTICE. Unless waived by adjoining owners, at least 30 days prior to commencing the excavation the excavator shall notify, in writing, all owners of adjoining buildings of his or her intention to excavate. The notice shall state that adjoining buildings may require permanent protection. The owners of adjoining property shall have access to the excavation site for the purpose of protecting their buildings.

(5) EMPLOYEES NOT LIABLE. No worker who is an employee of an excavator may be held liable for his or her employer's failure to comply with this section.

(6) FAILURE TO COMPLY; INJUNCTION. If any excavator fails to comply with this section, any aggrieved person may commence an action to obtain an order under ch. 813 directing such excavator to comply with this section and restraining the excavator from further violation thereof. If the aggrieved person prevails in the action, he or she shall be reimbursed for all his or her costs and disbursements together with such actual attorney fees as may be approved by the court."

INSERT PAGES
IBC CHAPTER 34

To be inserted between pages 540 & 541.

Comm 62.3400 Existing structures. The requirements in IBC chapter 34 are not included as part of this code.

INSERT PAGES
IBC CHAPTER 35

To be inserted between pages 554 & 555.

Comm 62.3500 Referenced standards. (1) INTRODUCTION. Substitute the following wording for the introductory paragraph in IBC chapter 35: This chapter lists the standards that are referenced in various sections of this document. The standards are listed herein by the promulgating agency of the standard, the standard identification, the effective date and title, and the section or sections of this document that reference the standard. The application of the referenced standards shall be as specified in s. Comm 61.03 (1) (b) and (3) (a).

Note: ANSI/ASAE standards may be purchased from the American Society of Agricultural Engineers, 2950 Niles Road, St. Joseph, MI 49085-9659.

ASTM standards may be purchased from ASTM International, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959

NFPA standards may be purchased from the National Fire Protection Association, One Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

Copies of the standards adopted under this section are on file in the offices of the department, the secretary of state, and the revisor of statutes.

INSERT PAGES
IBC CHAPTER 35

To be inserted between pages 560 & 561.

Comm 62.3500 Referenced standards. (3) ADDITIONS. This is a department rule in addition to the requirements in IBC chapter 35: The following standards are hereby incorporated by reference into this code:

(a) ASTM C 578-1995, Standard Specification for Rigid Cellular Polystyrene Thermal Insulation.

INSERT PAGES
IBC CHAPTER 35

To be inserted between pages 568 & 569.

Comm 62.3500 Referenced standards. (3) ADDITIONS. This is a department rule in addition to the requirements in IBC chapter 35: The following standards are hereby incorporated by reference into this code:

- (b) NFPA 30A-2000, Code for Motor Fuel Dispensing Facilities and Repair Garages.
- (c) NFPA 45-2004, Standard on Fire Protection for Laboratories Using Chemicals.

INSERT PAGES
IBC CHAPTER 35

To be inserted between pages 570 & 571.

Comm 62.3500 Referenced standards. (3) ADDITIONS. This is a department rule in addition to the requirements in IBC chapter 35: The following standards are hereby incorporated by reference into this code:

(d) NFPA 750-1996, Standard on Water Mist Fire Protection Systems.

INSERT PAGES
IBC CHAPTER 35

To be inserted between pages 572 & 573.

Comm 62.3500 Referenced standards. (3) ADDITIONS. This is a department rule in addition to the requirements in IBC chapter 35: The following standards are hereby incorporated by reference into this code:

(e) UL 2034–2005, Single and Multiple State Carbon Monoxide Alarms.

(f) UL 2075–2007, Gas and Vapor Detectors and Sensors.

Note: UL standards may be purchased for Underwriters Laboratories, Inc., 333 Pfingsten Road, Northbrook, IL 60062–2096.

INSERT PAGES
IBC APPENDICES

To be inserted between pages 574 & 575.

Comm 62.3600 Appendices. (1) EXCLUSIONS. The provisions in IBC Appendices A, B, D, and F to K are not included as part of this code.

INSERT PAGES
IBC APPENDICES

To be inserted between pages 578 & 579.

Comm 62.3600 Appendices. (2) APPENDIX C. The provisions in IBC Appendix C apply to Group U agricultural buildings, as described in IBC section C 101.1, that are not exempt from this code as outlined in ss. Comm61.01 and 61.02 (2) and (3).