

NON PRECEDENT PETITION

CODE SECTION: COMM 82.30(3)

DATE: September 14, 1998

CODE REQUIREMENT: The rule requires that the load factor on drain piping shall be computed in terms of dfu values specified in Table 82.30-1. Table 82.30-1 specifies the smallest receptor of indirect waste as 1 1/2" and 2 dfu.

VARIANCE REQUESTED: Allow the installation of 1 1/4" receptors for the discharge from water heater t&p valves.

KEY WORDS: Discharge, t&p relief, receptors

RESTRICTIONS:

CONDITIONS:

none listed

COMMENTS: The IPC and UPC plumbing codes have values for a 1 1/4" receptor, it is rated at 1 DFU

DATE PUT ON LIST: 07/30/01

BY: Lynita Docken