



**Tommy G. Thompson, Governor**  
**Brenda J. Blanchard, Secretary**

August 8, 2000

MODERN MAINTENANCE PRODUCTS  
H&S INTERNATIONAL, INC.  
MARK L. SCHWAMB  
3214 SYENE RD.  
MADISON WI 53713

NEPTUNE RESEARCH, INC.  
1683 LATHAM RD.  
WEST PALM BEACH FL 33409

Re: Description: PIPES AND FITTINGS, REPAIR KITS  
Manufacturer: NEPTUNE RESEARCH, INC.  
Product Name: SYNTHO GLASS  
Model Number(s): PPS, SG, CPR, NPP, PRK, JRK, BA and SS  
Product File No: 20000208

The Department has stopped the review of this plumbing product for the following reason(s):

- Individual product review and approval of the above referenced product is not required. This product is acceptable for use in Wisconsin, if the product must meet the following performance and material requirements of chapters Comm 82 and 84, Wis. Adm. Code. Proof of conformance to the below listed code requirement is the sole responsibility of the manufacturer.
  - Installation of this product on gravity flow drains shall not create a reduction in the pipe area in the direction of flow, s. Comm 82.30 (9) (c) 2.
  - Installation of this product on gravity flow drains shall create a gas tight repair that will withstand a test pressure of 4.34 psig, s. Comm 82.21.
  - Installation of this product on pressurized drains shall have a working pressure and temperature rating equal to or greater than the pressure and temperature it will be subjected for the specific installation, s. Comm 84.30 (2) (e).
  - Installation of this product on water piping shall utilize materials suitable for contact with potable water for the materials that come in contact with the water, s. Comm 84.40 (4)
  - Installation of this product on water services and private water mains shall have a working pressure rating of 150 psig at 73.4°F, s. Comm 84.40 (4) (d).
  - Installation of this product on water distribution piping shall have a working pressure rating of 100 psig at 180°F, s. Comm 84.40 (4) (e) 1.
  - Installation of this product on water distribution piping installed underground for exterior turf sprinkler system shall have a working pressure rating of 150 psig at 73.4°F, s. Comm 84.40 (4) (e) 2.
- Since this product does not require department product review, your review fee of \$300.00 will be refunded to the payer under separate cover.

This product file is considered closed.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
email: Mbeckwith@commerce.state.wi.us