Studor Mini-Vent
Table 1

Maximum Drainage Fixture Units[a] Served	Maximum developed Distance of Vent to Connection of Air Admittance Valve (AAV)		
	1-1/4" Vent Diameter	1-1/2" Vent Diameter	2" Vent Diameter
1	35	NL	NL
3	28	140	NL
6	NP[c]	100	200
20	NP	60	110
160	NP	NP	25

Notes: a: Drainage Fixture Units based on ch. Comm 82, Wis. Adm. Code
b: NL means no limit
c: NP means not permitted
d: Not more than two (2) water closets or similar type fixtures of four (4) or more drainage fixture units.

Figure 5

Studor Maxi-Vent
Table 1

Maximum Drainage Fixture Units[a] Served	Maximum developed Distance of Vent to Connection of Air Admittance Valve (AAV)	
	3" Vent Diameter	4" Vent Diameter
20	NL	NL
160	300	NL

Notes: a: Drainage Fixture Units based on ch. Comm 82, Wis. Adm. Code
b: NL means no limit

Figure 6