



commerce.wi.gov

Wisconsin
Department of Commerce

Evaluation #

New Product 20079024
Replaces 200724-I

Safety & Buildings Division
201 West Washington Avenue
P.O. Box 2658
Madison, WI 53701-2658

Wisconsin Building Products Evaluation

Material

GACO Green 052
Polyurethane Insulation
(Spray-Applied)

Manufacturer

GACO Western LLC
P.O. Box 646
Waukesha, WI 53187

SCOPE OF EVALUATION

GENERAL: This report evaluates the use of the GACO Green 052 polyurethane insulation (spray-applied), manufactured by GACO Western LLC. GACO Green 052 an open-cell rigid spray polyurethane insulation was evaluated as a foamed-in-place insulation for use in brick and concrete block cavities, pre-cast hollow core panels and planks, and wood frame, in new and existing construction.

GACO Green 052 foamed-in-place polyurethane insulation was evaluated in accordance with the fire safety requirements for foam plastic, and thermal performance, for the codes listed below.

The **Comm** requirements below in accordance with the current **Wisconsin Uniform Dwelling Code for 1- and 2-family dwellings:**

- **Foam Plastic Material:** GACO Green 052 foamed-in-place polyurethane insulation was evaluated in accordance with the fire safety requirements of **s. Comm 21.11.**
- **Thermal Performance:** GACO Green 052 foamed-in-place polyurethane insulation was evaluated in accordance with the thermal performance requirements of **Subchapter VI, ss. Comm 22.20, 22.21, 22.23, 22.25, 22.27, 22.28, and 22.31.**

The **IBC** requirements below in accordance with the current **Wisconsin Amended ICC Code:**

- **Foam Plastic:** GACO Green 052 foamed-in-place polyurethane insulation was evaluated in accordance with the fire safety requirements of **ss. IBC 2603.1, 2603.2, 2603.3 and s. IBC 2603.4.**
- **Thermal Performance:** GACO Green 052 foamed-in-place polyurethane insulation was evaluated in accordance with the thermal performance requirements of **s. Comm 63.1018(2)(a)1., (c).**

DESCRIPTION AND USE

GACO Green 052 is a two-component polyurethane spray foam (non-structural), made by combining an Isocyanate (A) Component with an all water blown (B) Component has a nominal in-place density of 0.5 pounds per cubic foot.

GACO Green 052 foamed-in-place polyurethane insulation was evaluated as a foamed-in-place insulation for use in brick and concrete block cavities, pre-cast hollow core block and plank in new and existing residential and commercial and frame construction.

TESTS AND RESULTS

Tests for surface-burning characteristics for GACO Green 052 foamed-in-place polyurethane insulation were conducted in accordance with ASTM E84. The flame spread index was determined to be **25** and the smoke-developed index was determined to be **250**.

Thermal conductivity is as follows: the thermal conductivity of GACO Green 052 foamed-in-place polyurethane insulation has an **R-value** of **3.7** per inch of thickness.

Testing was conducted by Intertek ETL Semko, Report Number 3127781COQ-006, August 9, 2007.

LIMITATIONS OF APPROVAL

General: GACO Green 052 foamed-in-place polyurethane insulation **is approved** for installation in brick and concrete block cavities, pre-cast hollow core block and plank in new and existing residential and commercial and frame construction.

GACO Green 052 foamed-in-place polyurethane insulation shall be installed by licensed, certified GACO Western LLC dealers in accordance with the manufacturer's recommendations.

The **Comm** limitation requirements below are in accordance with the current **Wisconsin Uniform Dwelling Code (UDC), for 1- & 2-family dwellings:**

- **Foam Plastic:** GACO Green 052 foamed-in-place polyurethane insulation shall be separated from the building interior with a thermal barrier as required by **s. Comm 21.11 (1)**.
- **Thermal Performance:** GACO Green 052 foamed-in-place polyurethane insulation shall meet the thermal performance requirements of **Subchapter VI, ss. Comm 22.20, 22.21, 22.23, 22.25, 22.27, 22.28, and 22.31**. Calculations shall be signed, sealed and submitted in accordance with **s. Comm 22.31**.

The **IBC** limitations below are in accordance with the current **Wisconsin Amended IBC 2000 Code:**

- **Foam Plastic:** GACO Green 052 foamed-in-place polyurethane insulation shall be separated from the building interior with a thermal barrier as required by **s. IBC 2603.4**.
- **Thermal Performance:** GACO Green 052 foamed-in-place polyurethane insulation shall meet the thermal performance requirements of **s. Comm 63.1018(2)(a)1., and (c)**. Calculations shall be signed, sealed and submitted in accordance with **s. Comm 63.1019**.

GACO Green 052 foamed-in-place polyurethane insulation is only allowed in accordance with **s. IBC 2603.3**.

This approval will be valid through December 31, 2012, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department. The product approval is applicable to projects approved under the current edition of the applicable codes. This approval may be void for project approvals made under future applicable editions. The Wisconsin Building Product Evaluation number must be provided when plans that include this product are submitted for review.

DISCLAIMER

The department is in no way endorsing or advertising this product. This approval addresses only the specified applications for the product and does not waive any code requirement not specified in this document.

Revision Date:

Approval Date: February 15, 2008 By: _____

Lee E. Finley, Jr.
Product & Material Review
Integrated Services Bureau

200724-I-.doc