



April 22, 2002

VILLAGE OF SLINGER
300 SLINGER RD.
PO BOX 227
SLINGER WI 53086-0227

BONESTROO, ROSENE, ANDERLIK &
ASSOCIATES
ALLAN SCHMIDT
1516 W MEQUON RD.
MEQUON WI 53092

Re: Description: POOLS
Manufacturer: BONESTROO, ROSENE, ANDERLIK & ASSOCIATES
Product Name: SWIM POND
Model Number(s): Slinger Swim Pond - Firemen's Park Annex
645 Baehring Drive
Product File No: 20020027

The specifications and/or plans for this experimental swim facility have been reviewed and determined to be in compliance with chapter Comm 90, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an experimental approval to s. Comm 90 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2007.

This experimental approval is contingent upon compliance with the following stipulation(s):

- The swim facility shall adhere to the Department of Health and Family Services requirements for water testing protocol, water quality parameters, closure thresholds, and reopen procedures.
- The swim facility shall keep records and report data and submit them for review as required by the Department of Health and Family Services.
- A water meter shall be installed that exclusively measures the volume of water discharged into the swim basin.
- The Village of Slinger shall keep daily records of the amount of water added to the swim basin and submit them upon request to the department.
- Signage shall be posted giving notice that the water quality at the facility does not meet water quality parameters of a swimming pool and if patrons have questions concerning water quality they are to contact management of the swim facility.
- The below water line portion of the diving structure shall be padded or shall be made distinctly visible so that an underwater swimmer is able to see the structure from a distance of at least five feet with uncorrected vision.
- The time limit for this experiment is five years at which time it will either be extended, codified, or terminated. This experiment may be terminated at any time if the departments of Commerce or Health and Family Services determine it is not being maintained as stated in this approval.

VILLAGE OF SLINGER

Page 2

April 22, 2002

Product No. 20020027

- The Department of Natural Resources shall be contacted and proper permits obtained for discharge water.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen A Jones

Swimming Pool and Private Sewage Plan Reviewer

phone: (608) 267-5265

fax: (608) 267-9566

email: gjones@commerce.state.wi.us