



April 8, 2002

TUSCHL SEPTIC SYSTEMS, INC.
CHARLES TUSCHL

PO BOX 293
WHITELAW WI 54247-0293

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: TUSCHL SEPTIC SYSTEMS, INC.
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP OR HOLDING
Model Number(s): 1200/800
(48" L.L., 25.18/16.53 GAL/IN., 48" MAX. DEPTH OF BURY, 959 G.P.D. WHEN USED AS
A SEPTIC/SEPTIC TANK OR 579 G.P.D. WHEN USED AS A SEPTIC/PUMP TANK
BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20020117

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2007.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - A-Lok X-Cel by A-Lok Products, Inc.
 - Bottom and side pipe openings for pump and holding tanks.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Four or six-inch inlet or outlet.
 - Neenah bolted manhole cover and frame.
 - Two and 1/4 inch diameter knock out in riser for electrical wiring.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manner that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.

TUSCHL SEPTIC SYSTEMS, INC.
Product File No. 20020117
Page 2
April 8, 2002

This approval supercedes the approval issued on June 15, 2000 under product file number 20000554.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Lee E. Finley, Jr.
Bureau of Integrated Services
Department of Commerce
Phone (608) 261-0450
Fax (608) 267-9566
Email lfiney@commerce.state.wi.us