

December 20, 2002

AQUAPOINT, INC.
JOHN LAFRENIERE
241 DUCHAINE BLVD.
NEW BEDFORD MA 02745

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: AQUAPOINT, INC.
Product Name: BIOCLERE
Model Number(s): 30/32
Product File No: 20020494

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2007.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- When this product is used for denitrification of the wastewater, the wastewater in the septic tank must have a nitrate value greater than 3 mg/l and a dissolved oxygen value equal to or less than 0.5 mg/l.
- When this product is used for denitrification of the wastewater, the size of the septic tank must take into consideration the impact of recirculation on detention time.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

AQUAPOINT, INC.
Page 2
December 20, 2002

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov