



March 27, 2003

EVERGREEN CONCRETE PRODUCTS  
RAND RUSIN  
1681N N 2ND DR  
STEVENS POINT WI 54481

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: EVERGREEN CONCRETE PRODUCTS  
Product Name: SEPTIC, HOLDING, PUMP OR GREASE INTERCEPTOR  
Model Number(s): 1250  
(47.0" L.L., 27.6 GAL/IN. 48" MAX. DEPTH OF BURY, 622 G.P.D. WHEN USED AS A  
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL  
WASTEWATER)  
Product File No: 20030113

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2008.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product is approved to use the following:
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Press Seal "Cast-A-Seal" by Press Seal Gasket Corp.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

EVERGREEN CONCRETE PRODUCTS

Page 2

March 27, 2003

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: [mike.beckwith@wi.gov](mailto:mike.beckwith@wi.gov)