



August 22, 2003

ZOELLER PUMP CO
KENNETH ZOELLER
3649 CANE RUN RD
LOUISVILLE KY 40211-1961

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: ZOELLER PUMP CO
Product Name: SEPTIC TANK OUTLET FILTER
Model Number(s): 5000-0007
Product File No: 20030167

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2008.

This approval is contingent upon compliance with the following stipulation(s):

- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product may be installed as an outlet baffle of septic tanks or compartments that have a maximum daily flow rate of no more than 4000 gallons per day.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov