



August 15, 2003

ONEIDA CONCRETE PRODUCTS, INC.
RICK JOHNSON

PO BOX 357
RHINELANDER WI 54501

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: ONEIDA CONCRETE PRODUCTS, INC.
Product Name: SEPTIC, HOLDING OR PUMP
Model Number(s): 1000
(40 .25" L.L., 25.0 GAL/IN., 72" MAX. DEPTH OF BURY, 482 G.P.D. WHEN USED AS A
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20030252

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2004.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
 - Press Seal "Cast-A-Seal" gaskets
 - Dual or triple inlets at end of tank with one access or multiple openings above each inlet.
 - Dual or triple outlets end of tank with one access or multiple openings above each outlet.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Tuf-Tite manhole risers and covers.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six inch inlet and outlet openings.
 - "E-Z Set" access risers RIS-2012, RIS-2406 & RIS-2412.

ONEIDA CONCRETE PRODUCTS, INC.
Product File Number 20030252
Page 2
August 15, 2003

This approval supercedes the approval issued on July 24, 2000 under product file number 20000914.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20000914.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Lee E. Finley, Jr.
Bureau of Integrated Services
Department of Commerce
Phone (608) 261-0450
Fax (608) 267-9566
Email lfinley@commerce.state.wi.us



August 15, 2003

ONEIDA CONCRETE PRODUCTS, INC.
RICK JOHNSON

PO BOX 357
RHINELANDER WI 54501

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: ONEIDA CONCRETE PRODUCTS, INC.
Product Name: SEPTIC, HOLDING OR PUMP
Model Number(s): 800
(33.5" L.L., 24.8 GAL/IN. 72" MAX. DEPTH OF BURY, 398 G.P.D. WHEN USED AS A
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20030253

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2007.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
 - Press Seal "Cast-A-Seal" gaskets
 - Dual or triple inlets at end of tank with one access or multiple openings above each inlet.
 - Dual or triple outlets end of tank with one access or multiple openings above each outlet.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Tuf-Tite manhole risers and covers.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six inch inlet and outlet openings.
 - "E-Z Set" access risers RIS-2012, RIS-2406 & RIS-2412.

ONEIDA CONCRETE PRODUCTS, INC.
Product File Number 20030253
Page 2
August 15, 2003

This approval supercedes the approval issued on June 10, 2002 under product file number 20020228.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020228.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Lee E. Finley, Jr.
Bureau of Integrated Services
Department of Commerce
Phone (608) 261-0450
Fax (608) 267-9566
Email lfmley@commerce.state.wi.us