

December 23, 2003

KNIGHT TREATMENT SYSTEMS
JAMES E. KNIGHT
281 COUNTY ROUTE 51A
OSWEGO NY 13126

KNIGHT TREATMENT SYSTEMS, INC.
DOUGLAS J. NELSON
W3082 EAST GATE DR
WATERTOWN WI 53094

Re: Description: CHEMICAL OR PHYSICAL RESTORATION FOR POWTS
Manufacturer: KNIGHT TREATMENT SYSTEMS, INC.
Product Name: WHITE KNIGHT MICROBIAL INOCULATOR/GENERATOR
Model Number(s): WK-40 AND WK-78
Product File No: 20030401

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2008.

This approval is contingent upon compliance with the following stipulation(s):

- This product must be utilized in accordance with the manufacturer's printed installation instructions and this product approval. If there is a conflict between the manufacturer's installation instructions and the product approval, the product approval requirements will take precedence.
- The elevation of the system's infiltrative surface must be above the estimated highest groundwater elevation or bedrock by the distance prescribed in column entitled "Fecal Coliform >10000 cfu/100 ml" in Table Comm 83.44-3, Wis. Adm. Code.
- A copy of this approval letter and the manufacturer's printed installation instructions must be supplied to the buyer of this product.
- This product must be installed in the second compartment of a septic tank or in the second half of a single compartment septic tank.
- The outlet baffle of the septic tank, which has this product installed, must have installed an effluent filter capable of filtering particles of 1/8 inch in size or larger.
- This product must be installed by a properly licensed plumber.
- A state Sanitary Permit must be obtained when this product is installed.
- The IOS-500 inoculants must be exchanged at least on an annual basis.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

KNIGHT TREATMENT SYSTEMS

Page 2

December 23, 2003

Sincerely,

Michael J. Beckwith, CIPE

Plumbing Product Reviewer

phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wisconsin.gov