



commerce.wi.gov

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor
Mary P. Burke, Secretary

January 22, 2004

ADS-- ADVANCE DRAINAGE SYSTEMS
ROGER L BALDWIN
21 CARRIGE LANE
BURNSVILLE MN 55337-4045

Re: Description: PIPES AND FITTINGS, POLYETHYLENE
Manufacturer: ADS-- ADVANCE DRAINAGE SYSTEMS
Product Name: SURELOK BLUE SEAL
Model Number(s): PIPE:12", 15", 18", 24", 30", 36", 42", 48" AND 60"; PVC REPAIR KIT: 12",15",18",24",30"
END CAPS: 12",15",18",24",30"; ADAPTERS TO SMOOTH HDPE: 12",15",18",24",30";
ECCENTRIC REDUCERS:
15x12,18x12,18x15,24x12,24x15,24x18,30x12,30x15,30x18,30x24,36x12,36x15,36x18,36x
24,36x30; TAP
REDUCERS:15x12,18x12,18x15,24x12,24x15,24x18,30x12,30x15,30x18,30x24; 22.5
DEGREE ELBOWS: 12",15",18",24",30",36",42",48",60"; 45 DEGREE ELBOWS:
12",15",18",24",30",36",42",48",60; 90 DEGREE SINGLE MITER ELBOW:
12",15",18",24",30",36",42",48",60"; 90 DEGREE DOUBLE MITER ELBOW:
12",15",18",24",30",36",42",48",60; TEE:12",15",18",24",30",36",42",42",48",60; REDUCING
TEE:
15x12,18x12,18x15,24x12,24x15,24x18,30x12,30x15,30x18,30x24,36x12,36x15,36x18,36x
24,36x30,42x12,42x15,42x18,42x24,42x30,42x36,48x12,48x15,48x18,48x24,48x30,48x36,
48x42; CROSS TEE: 12",15",18",24",30";WYE:12",15",18",24",30",36",42",48",60";
REDUCING WYE:
15x12,18x12,18x15,24x12,24x15,24x18,30x12,30x15,30x18,30x24,36x12,36x15,36x18,36x
24,36x30,42x12,42x15,42x18,42x24,42x30,42x36,48x12,48x15,48x18,48x24,48x30,48x36,
48x42; REDUCING TAP WYE:
15x12,18x12,18x15,24x12,24x15,24x18,30x12,30x15,30x18,30x24,36x12,36x15,36x18,36x
24,36x30,42x12,42x15,42x18,42x24,42x30,42x36,48x12,48x15,48x24,48x30,48x36,48x12

Product File No: 20030581

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (2) and (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2009.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain or vent use(s):
 - a. Sanitary sewer gravity flow
 - b. Storm sewer gravity flow

- Approval is issued for this product because the design of the product meets the intent of s. Comm 84.30 and 84.40, Wis. Adm. Code that requires piping materials to be suitable for such use and have watertight joints. The intent of the code is met since this product provides an acceptable material and joints for gravity flow sanitary and storm sewer pipe.

January 22, 2004

- Pipe and fittings sizes of 12" through 60" shall meet AASHTO Standard M-294 and be labeled with Hancor Logo, Pipe Size, Date Code, AASHTO M-254. The maximum space between labels on pipe must not exceed 11.5 feet. Each fitting shall be labeled.

This approval supersedes the approval issued on INSERT DATE under product file number #####.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov