



commerce.wi.gov

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor
Mary P. Burke, Secretary

May 20, 2004

ADS-- ADVANCE DRAINAGE SYSTEMS
ROGER L BALDWIN
21 CARRIGE LANE
BURNSVILLE MN 55337-4045

HANCOR, INC.
APPLICATION ENGINEERING MANAGER
BILL VANHOOSE
401 OLIVE ST
FINDLAY OH 45840

Re: Description: PIPES AND FITTINGS, POLYETHYLENE
Manufacturer: HANCOR, INC.
Product Name: HANCOR SURE-LOK WT PIPE AND FITTINGS
Model Number(s): SURE-LOK WT PIPE: 4",6",8",10"
90 DEGREE SINGLE MITER ELBOW:4",6",8",10";90 DEGREE DOUBLE MITER ELBOW:
4",6",8",10";45 DEGREE ELBOWS:4",6",8",10";22.5 DEGREE
ELBOWS:4",6",8",10";TEE:4",6",8",10";CROSS TEE:4",6",8",10";REDUCING
TEE:6x4,8x4,8x6,10x4,10x6,10x8;REDUCING TAP
TEE:6x4,8x4,8x6,10x4,10x6,10x8;WYE:4",6",8",10";REDUCING
WYE:6x4,8x4,8x6,10x4,10x8;REDUCING TAP WYE:6x4,8x4,8x6,10x4,10x6,10x8;
ECCENTRIC REDUCERS:6x4,8x4,10x4,10x6,10x8;TAP
REDUCERS:6x4,8x4,8x6,10x4,10x6,10x8;PVC REPAIR KIT: 10";END CAPS:
4",6",8",10";ADAPTERS TO SMOOTH HDPE:4",6",8",10"
Product File No: 20030582

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (2) and (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2009.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain or vent use(s):
 - a. Effluent piping gravity flow non-perforated
 - b. Sanitary drain and vent piping . . gravity flow underground
 - c. Sanitary sewer gravity flow
 - d. Storm drain and vent piping . . . gravity flow underground
 - e. Storm sewer gravity flow
- Each length of pipe must be marked at an interval not to exceed ten feet along the length of the product with an embossed logo or heat stamp including the manufacturer's name (Hancor Inc.), the product size, the manufactured date code, and the specification AASHTO M252. In addition, each section of the pipe shall have a UPC identification sticker attached to the bell end listing the product diameter, length, and product name (SURE-LOK WT) The product will also have a blue protective film over the gasketed spigot end.

All fittings shall have a UPC identification sticker attached, listing the product diameter or description and product name. In addition, each fitting shall have the date of manufacturer hot stamped or writing on the product.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

ADS-- ADVANCE DRAINAGE SYSTEMS

Page 2

May 20, 2004

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov