



Jim Doyle, Governor
Cory L. Nettles, Secretary

PANKOW'S PREC AST SEPTIC TANK COMPANY April 28, 2004
JEFF OR PUAL PANKOW
N887 MIDWAY LANE
WATERTOWN WI 53098

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: PANKOW'S PREC AST SEPTIC TANK COMPANY
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP OR HOLDING
Model Number(s): P.S. 1000/750 LOW PROFILE
 (39" L.L., 25.8/19.4 GAL/IN., 48" MAX. DEPTH OF BURY, 844 G.P.D. WHEN USED AS A
 SEPTIC/SEPTIC TANK OR 482 G.P.D. WHEN USED AS A SEPTIC/PUMP TANK BASED
 ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20040152

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank wall, tank cover or access cover.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.

This approval supercedes the approval issued on June 20, 2000 under product file number 20000805.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20000805.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Lee E. Finley, Jr.
Bureau of Integrated Services