

April 27, 2004

OATEY  
ROSS E. KINGMAN  
4700 W 160TH ST  
CLEVELAND OH 44135-2632

Re: Description: AIR ADMITTANCE VALVES, ALTERNATE PLUMBING SYSTEM  
Manufacturer: OATEY  
Product Name: SURE VENT II  
Model Number(s): 1-1/2", 39005, 39015, 39020; 1-1/2" - 2", 39016, 39017, 39018, AND 39019  
Product File No: 20040175

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.31 (3) (a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2009.

This approval supersedes the approval issued on April 10, 2002 under product file number 20002232.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed in accordance with the manufacturer's printed instructions, system approval, plan approval, and Wis. Adm. Code. If there is a conflict between the manufacturer's instructions and the plan approval, system approval or Wis. Adm. Code, the Wis. Adm. Code, plan approval and system approval will take precedence.
- This product must hold a pressure equal to one-inch water column for five minutes after the product is installed or immediately prior to installation.
- This product must be installed in the vertical position (plus or minus 15 degrees from plumb).
- This product may only be installed in a vent system that has the required three-inch vent per s. Comm 82.31 (3) (b), Wis. Adm. Code extending to the outside atmosphere.
- The vent system being served by this product may have horizontal offsets located less than 36 inches above the floor on which the fixtures are installed providing the vent does not connect to another vent.
- Branches which have fixtures served by this product must comply with all of the following.
  - When connected to a stack which has four (4) or more branch intervals above the branch connection, the branch must be provided with a relief vent located between most downstream fixture and the stack, and
  - The branch must not connect to any horizontal drain within 20 pipe diameters downstream of the base of a two (2) inch or larger drain stack.

- This product may not serve as a vent termination point for any of the following.
  - Vents installed to relief positive pressures,
  - vents serving chemical waste system,
  - vents serving POWTS holding tank or, POWTS treatment tank,
  - a stack vent serving two (2) or more branch intervals,
  - a vent stack that is required in accordance with s. Comm 82.31 (4) (a),
  - a vent serving a sump, or
  - a vent serving an automatic clothes washer standpipe.
  
- This product may not be located in any of the following areas.
  - An area subject to freezing,
  - an enclosed stairwell,
  - an area subject to positive pressure conditions for more than 12 continuous hours,
  - an area utilized as supply or return air plenum, or
  - a pit, vault or depression which is below the adjacent grade or floor level.
  
- This product may only serve as a termination point for the following types of vents serving a maximum two inch diameter drain:
  - branch vent,
  - circuit vent,
  - common vent,
  - individual vent,
  - stack vent,
  - wet vent, or
  - vent stack.
  
- This product must be located and the system sized in accordance with Table 1.

Oatey Sure-Vent II  
 Table 1

Maximum Drainage Fixture Units Served (see note a)	Maximum Developed Distance of Vent to Connection of Air Admittance Valve		
	1-1/4" Vent Diameter	1-1/2" Vent Diameter	2" Vent Diameter
1	35	NL (see note b)	NL
3	28	140	NL
6 (see note c)	NP (see note d)	100	200

- Notes: a: Drainage Fixture Units based on ch. Comm 82, Wis. Adm. Code  
 b: NL means no limit  
 c: No water closets or similar type fixtures of four (4) or more drainage fixture units  
 d: NP means not permitted

- This product must be located:
  - within a heated area of the building,
  - a minimum of 4 inches above the weir of the highest fixture trap being served (see note a),
  - no more than 20 inches below the flood rim of any fixture served by this product (see note a),
  - in an accessible area,
  - within a ventilated space that allows air to enter the product and has an opening with an area of at least one-inch to the building air, and
  - in accordance with s. Comm 82.31 (9), Wis. Adm. Code.

Note a: The distance is measured from termination of the vent pipe to the point noted in the stipulation.

Oatey  
April 27, 2004  
Page 3 of 3  
Product File No.: 20040175

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Engineering Consultant-Plumbing Product Reviewer  
Bureau of Integrated Services  
Safety and Buildings Division  
Department of Commerce  
(608) 267-1401 Phone  
(608) 267-9566 Fax  
glen.schlueter@wi.gov Email

GWS:gws