



May 17, 2004

NTA, INC.
DAVID BARTS
305 N OAKLAND AVE.
PO BOX 490
NAPPANEE IN 46550

HART HOUSING GROUP, INC.
JOHN CUMMINS
66700 ST RD 19
WAKARUSA IN 46573

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: HART HOUSING GROUP, INC.
Product Name: MFGR. HOME PLUMBING SYSTEMS
Model Number(s): WATER RISER MODELS: KITCHEN SINK 1 AND 1A; TUB/SHOWER 2 AND 2A;
SHOWER 3 AND 3A; LAV & LAUNDRY SINK 4 AND 4A; TUB 5 AND 5A; WATER CLOSET
6 AND 6A; CLOTHES WASHER 7 AND 7A; ICE MAKER 8 AND 8A.
DRAIN AND VENT MODELS WITH AIR ADMITTANCE VALVES: KITCHEN SINK A, A1
AND A2; TUB, TUB/SHOWER OR UTILITY SINK B, B1 AND B2; LAV C, C1 AND C3;
SHOWER D, D1 AND D2.
DRAIN AND VENT MODELS WITHOUT AIR ADMITTANCE VALVES: KITCHEN SINK F,
F1 AND F2; LAV G, G1 AND G2; TUB OR TUB/SHOWER H, H1 AND H2; SHOWER I, I1
AND I2; CLOTHES WASHER J, J1 AND J2; WATER CLOSET K AND K1, WATER
CLOSET L AND L1; WATER CLOSET M AND M1; WATER CLOSET N AND N1.
Product File No: 20040210

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2009.

This approval is contingent upon compliance with the following stipulation(s):

- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The flowing water supply pressure at the point(s) of connection must be at least equal to 25 psig for water closets and 8 psig for outlets of all other fixtures supplies or the pressure required by the fixture manufacturer, whichever is greater.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

NTA, INC.
Page 2
May 17, 2004

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov