



commerce.wi.gov

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor
Mary P. Burke, Secretary

August 20, 2004

PRINSCO, INC.
CHATSWORTH FACILITY
JOE LARKINS
111 E PINE ST.
CHATSWORTH IL 60921

Re: Description: PIPES AND FITTINGS, POLYETHYLENE
Manufacturer: PRINSCO, INC.
Product Name: GOLDFLO DUAL WALL
Model Number(s): Pipe: 12, 15, 18, 24, 30 and 36
Fittings: SLEEVE COUPLER & GASKET: 12, 15, 18, 24; CROSS: 12, 15, 18, 24, 30, 36;
ELBOW - 22.5 degree: 12, 15, 18, 24, 30, 36; ELBOW - 45 degree: 12, 15, 18, 24, 30, 36;
ELBOW - 90 degree (2-Part): 12, 15, 18, 24, 30, 36; ELBOW - 90 degree (3-Part): 12, 15,
18, 24, 30, 36; TEE: 12, 15, 18, 24, 30, 36; WYE - 45 degree: 12, 15, 18, 24, 30, 36;
REDUCER: 12x4, 12x6, 12x8, 12x10, 15x4, 15x6, 15x8, 15x10, 15x12, 18x4, 18x6, 18x8,
18x10, 18x12, 18x15, 24x4, 24x6, 24x8, 24x10, 24x12, 24x15, 24x18, 30x4, 30x6, 30x8,
30x10, 30x12, 30x15, 30x18, 30x24, 36x4, 36x6, 36x8, 36x10, 36x12, 36x15, 36x18, 36x24,
36x30.
All sizes are in inches.
Product File No: 20040245

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (2) and (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2009.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain or vent use(s):
 - a. Sanitary sewer gravity flow
 - b. Storm sewer gravity flow
 - c. Stormwater infiltration piping gravity flow perforated
- This product must be labeled with the following information:
 - a. Manufacturer's name or trademark
 - b. Date of manufacture
 - c. National standard to which the pipe meets
 - d. Nominal size
 - e. Plant designation
 - f. Production line

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

PRINSCO, INC.
Page 2
August 20, 2004

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov