



May 25, 2004

MEADE CONSTRUCTION CO., INC.  
JOHN MEADE

PO BOX 76  
LODI WI 53555

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)  
Manufacturer: MEADE CONSTRUCTION CO., INC.  
Product Name: MICRO FAST 0.5, 0.75, 0.9 / PUMP  
Model Number(s): 1200/800  
(L.L.50.25", 24.13/15.93 GAL/IN. 48" MAX. DEPTH OF BURY )  
Product File No: 20040271

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This tank may only be used when installed with the Bio-Microbics, Inc., High Strength or Micro Fast sewage treatment apparatus.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

This approval supersedes the approval issued on INSERT DATE under product file number 20030398.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030398.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

MEADE CONSTRUCTION CO., INC.

Page 2

May 25, 2004

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: [mike.beckwith@wi.gov](mailto:mike.beckwith@wi.gov)