



June 17, 2004

NEECK CONCRETE PRODUCTS, LLC  
PRECAST  
HOWARD NEECK  
N13981 FLAMBEAU AVE  
PO BOX 246  
FIFIELD WI 54524

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: NEECK CONCRETE PRODUCTS, LLC  
Product Name: SEPTIC,HOLDING OR PUMP  
Model Number(s): 2500  
(56" L.L., 45.95 GAL/IN., 108" MAX. DEPTH OF BURY 1232 G.P.D WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)  
Product File No: 20040291

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

This approval supersedes the approval issued on July 19, 2000, under product file number 20000892.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20000892.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wi.gov  
SBD-10564-E (N.10/97)