

July 16, 2004

MIDWAY CONCRETE CORPORATION  
NEAL A. LUTZ  
P.O. BOX 757  
PLOVER WI 54467

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: MIDWAY CONCRETE CORPORATION  
Product Name: SEPTIC/SEPTIC, SEDIMENTATION, PUMP, SEPTIC/PUMP OR SEDIMENTATION/PUMP  
Model Number(s): MCC 2000/1000  
(43.5" L.L. , 45.48/22.75 GAL/IN., 42" MAX. DEPTH OF BURY, 1422 G.P.D. WHEN USED AS A SEPTIC/SEPTIC TANK OR 948 G.P.D. WHEN USED AS A SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)  
Product File No: 20040298

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2009.

This approval is contingent upon compliance with the following stipulation(s):

- The products produced by this manufacturer are approved to use the following:
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into the tank cover or manhole in lieu of an observation/vent opening.
  - Optional inlet opening through tank cover using pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover for holding or pump tank use.
  - Bottom openings for holding tank and for pump tank or compartment.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - This product is approved to use Press Seal "Cast-A-Seal" mechanical adapters for all pipe connections.
  - 4" or 6" PVC Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into the inlet and outlet openings of the tank in lieu of hub cast inlet or outlet opening.
  - Dual inlets at end of tank with one access opening above both inlets.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manner that will prevent waste from passing over the interior wall.

MIDWAY CONCRETE CORPORATION

Page 2

July 16, 2004

- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

This approval supersedes the approval issued on INSERT DATE under product file number 20000815.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20000815.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wi.gov