



July 16, 2004

HI-TECH HOUSING INC
BRIAN J. LEDBETTER
19319 CR. 8
BRISTOL IN 46507

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: HI-TECH HOUSING INC
Product Name: THE CONCEPT CLINIC
Model Number(s): 5014-WI
Product File No: 20040309

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2009.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 30 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum water supply fixture units allowed for the PEX piping is 8.0 wsfu for 5/8", 11.0 wsfu for 3/4", 20.5 wsfu for 1" and 34.0 wsfu for 1-1/4" tube size.
- The water heater relief valve shall discharge in accordance with s. Comm 82.40 (5)(d)5 of the Wisconsin Administrative Code.
- Water closets must be of the elongated bowl design in accordance with s. Comm 84.20 (5)(o) of the Wisconsin Administrative Code.
- Provide a valve on the water supply pipe that serves only the hose bibb for each of the hose bibbs. This valve is required in accordance with s. Comm 82.40 (4)(c)1, of the Wisconsin Administrative Code.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov