



October 13, 2004

FERNO-WASHINGTON, INC.
FERNO ILLE
RICHARD NICOL
70 WEIL WAY
WILMINGTON OH 45177-9371

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: FERNO-WASHINGTON, INC.
Product Name: FERNO ILLE MIXING CONSOLE
Model Number(s): 729
Product File No: 20040327

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2009.

This approval is contingent upon compliance with the following stipulation(s):

- A reduced pressure principle backflow preventer (ASSE 1013 or CAN/CSA B64.4) or air-gap must be installed on the water supply pipes serving this product.

This approval supersedes the approval issued on INSERT DATE under product file number 19990301.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov