



August 5, 2004

CAPE COD BIOCHEMICAL CO.  
RICK HOWE  
P.O. BOX 990  
POCASSET MA 02559

Re: Description: CHEMICAL OR BIOCHEMICAL SEPTIC TANK ADDITIVE  
Manufacturer: CAPE COD BIOCHEMICAL CO.  
Product Name: CCLS  
Model Number(s): NONE  
Product File No: 20040364

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This product does not replace the need for a regular program of inspection and maintenance, including having the treatment tank pumped out whenever the sludge and scum occupies one-third of the tank's liquid capacity.
- This product may not be introduced to a potable water supply system. This product may only be introduced to drain and waste systems.

This approval supersedes the approval issued on INSERT DATE under product file number #####.

Based on information supplied by the manufacturer and reviewed by the department, this approval recognizes that this plumbing product will not adversely affect bacterial action in the private sewage system, soil hydraulic conductivity in the absorption areas, or groundwater quality beneath the system when used in accordance with the manufacturer's instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

CAPE COD BIOCHEMICAL CO.

Page 2

August 5, 2004

Sincerely,

Glen W. Schlueter  
Engineering Consultant-Plumbing Product Reviewer  
Bureau of Integrated Services  
Safety and Buildings Division  
Department of Commerce  
(608) 267-1401 Phone  
(608) 267-9566 Fax  
gschlueter@commerce.state.wi.us Email

GWS:gws