



August 13, 2004

TUF-TITE
TED MEYERS
500 CAPITAL DR
LAKE ZURICH IL 60047-6713

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: TUF-TITE
Product Name: EFFLUENT FILTER
Model Number(s): EF-4
Product File No: 20040399

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This product may only be installed in the outlet tee of sewage treatment compartment or tank having a flow rate of no greater than 800 gpd.
- A 1.25" hole must be drilled in the top of the filter within an inch of the slots provide for venting prior to being installed in the outlet tee.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.

This approval supersedes the approval issued on INSERT DATE under product file number 19990741.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 19990741.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

TUF-TITE
Page 2
August 13, 2004

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov