



July 26, 2004

CREST PRECAST, INC.
STEVE MADER
609 KISTLER DR
LA CRESCENT MN 55947-1721

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: CREST PRECAST, INC.
Product Name: THE RIGHT SYSTEM
Model Number(s): 300GPD
Product File No: 20040403

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product consist of two multi-compartment tanks, to be utilized in the design of a split bed recirculating sand filter component for private onsite wastewater treatment system. One tank includes a septic/recirculation chamber, a sand filter dose chamber and an effluent dose chamber. The other tank includes a recirculation side chamber and an effluent side chamber for the sand filter tank. The internal components of the tanks are not included in this approval.
- Design of the POWTS system utilizing this product must conform to the Split Bed Recirculating Sand Filter System Component Manual for Private Onsite Wastewater Treatment Systems published on June 11, 1999, by Dept. of Commerce.
- The maximum daily wastewater flow which may discharge through this product is 300 gallons per day.

This approval supersedes the approval issued on June 22, 1999, under product file number 19990111.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 19990111.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov
SBD-10564-E (N.10/97)