



September 21, 2004

CREST HOMES
CMH MANUFACTURING
DAVID N. RICHTER
437 N MAIN ST.
PO BOX 1218
MIDDLEBURY IN 46540

CREST HOMES PLANT 981
CMH MANUFACTURING WEST INC
JIM GYOMORY
437 N MAIN ST
MIDDLEBURY IN 46540

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: CREST HOMES PLANT 981
Product Name: SINGLE FAMILY DWELLING RANCH
Model Number(s): 6028-338 (DWV-338.1, WS-338.1, and WS-338-2)
Product File No: 20040474

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2009.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 40 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov