



September 23, 2004

NTA, INC.
DAVID BARTS
305 N OAKLAND AVE.
PO BOX 490
NAPPANEE IN 46550

RITZ-CRAFT CORP. OF MI, INC.
GLEN EMRICK
118 DEAL PKWY
PO BOX 5
JONESVILLE MI 49250

Re: Description: **PREFABRICATED PLUMBING SYSTEM**
Manufacturer: **RITZ-CRAFT CORP. OF MI, INC.**
Product Name: **ENCORE RANCH**
Model Number(s): **NR6223**
Product File No: **20040487**

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2009.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 24 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov