

April 30, 2007

STORMTECH, LLC  
DAVID J MAILHOT  
20 BEAVER RD  
WETHERSFIELD CT 06190

Re: Description: STORMWATER DETENTION AND/OR INFILTRATION SYSTEM  
Manufacturer: STORMTECH, LLC  
Product Name: STORMTECH UNDERGROUND STORMWATER CHAMBERS  
Model Number(s): STORMTECH SC-740 CHAMBER  
Product File No: 20040528

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (6)(h) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2010.

This approval supersedes the approval issued on February 14, 2005, under product file number 20040528.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040528.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Prior to installation of this product, plans and specifications must be submitted to the department or to an approved agent municipality for review and approval in accordance with s. Comm 82.20 (1) of the Wis. Admin. Code. Written approval for the plans and specifications shall be obtained prior to installation of the product.
- This product is approved for the following uses:
  - Stormwater and clearwater subsurface detention system,
  - Stormwater and clearwater subsurface infiltration system, or
  - Stormwater and clearwater subsurface detention/infiltration system
- This product must be permanently labeled identifying the manufacturer and model number (StormTech SC-740).
- When this product is installed as a subsurface detention/infiltration system or an infiltration system, the design and installation must be in accordance with the manufacturer's printed Design Manual (S070104HP-5) and Installation Instructions (S081203R-6), ch. Comm 82 and its Plan approval under s. Comm 82.20. When there is a conflict between manufacturer's installation instructions and plan approval or product approval stipulations, the plan approval or product approval stipulations will take precedence.
- When this product is installed as a subsurface detention system, the installation must be in accordance with the manufacturer's printed Design Manual (S070104HP-5), Installation Instructions (S081203R-6), liner instructions (S140404-0) and Tech Sheet #2 (rev. 9/9/04), ch. Comm 82, plan approval under s. Comm 82.20 and product approval stipulations. When there is a conflict between manufacturer's installation instructions and plan approval or product approval stipulations, the plan approval or product approval stipulations will take precedence.

- The installation of water proof membranes must be either PVC or Linear low density polyethylene (LLDPE) material having a minimum 30 mil thickness with all seams sealed. PVC membrane seams must be sealed using solvent cement. LLDPE membrane seams must be sealed using thermal welding.
- Inspection and maintenance of this product must be performed at intervals specified by the manufacturer (S070104HP-5) or in accordance plan approval or s. Comm 82.21, whichever is more restrictive.
- This product may be installed without a water proof membrane under the following conditions:
  1. The installation is for a subsurface detention system;
  2. The soils on which that detention system is placed have a maximum soil application rate of 0.2 gallons/square foot/day based upon morphological soil evaluation as listed in Comm Table 83.44-2 under the column for BOD5 and TSS > 30mg/L; and
  3. A geotextile fabric that meets the chamber manufactures specifications is place on the bottom of the product is required.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov