



4/27/2005 RE-ISSUED September 10, 2009

**ZOELLER PUMP CO.  
CUSTOMER SERVICE AND TECHNICAL SUPPORT  
3649 CANE RUN RD  
LOUISVILLE KY 40211-1961**

Re: Description: **SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER (see also SEWAGE TREATMENT TANKS)\***  
Manufacturer: ZOELLER PUMP CO.  
Product Name: ZOELLER PRESSURE EFFLUENT FILTER  
Model Number(s): 5000-0001, 5000-0002 & 5000-0003  
**[> 1/16 IN. FILTRATION; SEE MANUFACTURER FOR FILTRATION WITH SOCK]**  
Product File No: 20040629

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of APRIL 2010.**

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- **An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.**
- **Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.**
- The maximum daily wastewater flow that may discharge through this product is 375 gallons per day.
- The sizing calculations of the pressure distribution network must include head loss for this product based on flow rate, model and manufacturer pressure loss chart..

**\*This product type category has been changed to better reflect its use; it was previously approved as STA-sewage treatment apparatus; it is now listed as STAF- sewage treatment apparatus, effluent filter only.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov