

March 1, 2005

ANDRY RASMUSSEN & SONS, INC.
JEFF RASMUSSEN

PO BOX 66
CABLE WI 54821

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: ANDRY RASMUSSEN & SONS, INC.
Product Name: HOLDING, PUMP
Model Number(s): 500
(46" L.L., 11.44 GAL.IN., 72" MAX. DEPTH OF BURY)
Product File No: 20050032

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2010.

This approval is contingent upon compliance with the following stipulation(s):

- The products produced by this manufacturer are approved to use the following:
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or manhole in lieu of observation/vent opening.
 - Bottom pipe opening for siphon, pump and holding tanks.
 - Optional discharge opening from riser.
 - This product is approved to use Polylok II "High Pressure Seal", Press Seal "Cast-A-Seal", 4" fernco #44U-405 gasket, 4" Multi-Tite, 4" Jone-Tite SV gasket mechanical adapters for all pipe connections.
 - This product is approved to use Lead and Oakum joints for all pipe connections.
 - Tank covers may be sealed by the use of mortar or rubber butyl sealant.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on INSERT DATE under product file number #####.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #####.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

ANDRY RASMUSSEN & SONS, INC.

Page 2

March 1, 2005

Sincerely,

Lee E. Finley, Jr.
Bureau of Integrated Services
Department of Commerce
Phone (608) 261-0450
Fax (608) 267-9566
Email lee.finley@wi.gov