



Jim Doyle, Governor
Mary P. Burke, Secretary

March 15, 2005

SHAMROCK HOMES
PAT FLYNN, SR
1201 W MARKLEY RD
PLYMOUTH IN 46563

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: SHAMROCK HOMES
Product Name: RANCH
Model Number(s): 6733 FP (27-6 x 76-0) AND 6733(opt) (27-6 x 62-8)
Product File No: 20050057

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2010.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 32 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supercedes the approval issued on January 12, 2001, under product file number 20010246.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010246.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us