

March 24, 2005

LAKE SHORE BURIAL VAULT CO., INC.  
BRIAN MC QUESTION  
12780 LISBON ROAD  
BROOKFIELD WI 53005

DELTA ENVIRONMENTAL PRODUCTS INC  
MIKE CATANZARO  
PO BOX 969  
DENHAM SPRINGS LA 70727

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED  
Manufacturer: DELTA ENVIRONMENTAL PRODUCTS INC  
Product Name: WHITEWATER AEROBIC TREATMENT UNIT  
Model Number(s): DF-60-CA (600 GPD)  
Product File No: 20050061

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2010.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 600 gallons per day.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- When this product is installed with the optional POLYLOK effluent filter(s) model PL-122, this product is recognized to not discharge any solid or suspended solid exceeding 1/8 inch in diameter.
- When this product is installed with the "UV The Disenfactor" disinfection device and receives wastewater from dwellings and the flow through the UV disinfection does not exceed 6 gallons per minute, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L, and fecal coliform of less than or equal to 10,000 cfu/100ml.
- This product may be installed with PolyLok effluent filter model PL-122, and/or the "UV The Disenfactor" disinfection device in accordance with the manufacturer installation instructions.

This approval supercedes the approval issued on August 5, 2004, under product file number 20040368.

LAKE SHORE BURIAL VAULT CO., INC.

Page 2

March 24, 2005

Product File No: 20050061

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040368.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE

Plumbing Product Reviewer

phone: 608-266-6742

fax: 608-267-9566

e-mail: [mbeckwith@commerce.state.wi.us](mailto:mbeckwith@commerce.state.wi.us)