



March 22, 2005

HYDRO-ACTION IND.  
BOB HORNBUCKLE  
8645 BROUSSARD  
BEAUMONT TX 77713

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED  
Manufacturer: HYDRO-ACTION IND.  
Product Name: AP SERIES  
Model Number(s): AP-500 (500 GPD)  
Product File No: 20050101

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2010.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 500 gallons per day.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- Before this product is installed a warning label meeting the requirement of Comm s. 84.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mbeckwith@commerce.state.wi.us