

April 18, 2005

WIESER CONCRETE PRODUCTS, INC.
MARK WIESER
2815 RILEY ROAD
PORTAGE WI 53901

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: WIESER CONCRETE PRODUCTS, INC.
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, HOLDING TANK OR MICRO FAST 0 .5, 0.75 or
0.9/PUMP or HIGH STRENGTH FAST 1.0/PUMP
Model Number(s): W1425/975 BIO
Product File No: 20050104

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2010.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Side opening for when product is used as a holding tank.
 - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Four inch discharge opening in riser.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six inch inlet and outlet openings.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual inlets at end of tank with one access opening above each inlet.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

WIESER CONCRETE PRODUCTS, INC.

Page 2

April 18, 2005

- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- A tank with a minimum capacity of 750 gallons must be located upstream of this product whenever a Bio-Microbics 1.0 High Strength Fast unit is installed in this product.
- -This tank may only be used in conjunction with the Bio-Microbics Inc., Fast 0.5, 0.75 or 0.9 or High Strength Fast 1.0 units.

A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.

A copy of the approved plans and/or specifications is enclosed.

Previously approved as 20030268.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Lee E. Finley, Jr.
Bureau of Integrated Services
Department of Commerce
Phone (608) 261-0450
Fax (608) 267-9566
Email lee.finley@wi.gov