



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor
Mary P. Burke, Secretary

March 28, 2005

BRADLEY CORPORATION
THOMAS R EBERHARDY
W142 N9101 FOUNTAIN BLVD
PO BOX 309
MENONMONEE FALLS WI 53052-0309

Re: Description: FAUCET, LAVATORY
Manufacturer: BRADLEY CORPORATION
Product Name: AERADA 900 SERIES FUTURA FAUCET W/ACCUZONE INFRARED CONTROL (AZ)
Model Number(s): S53-141, S53-148, S53-285, S53-286, S53-186, S53-287, S53-288, 4FTMAR AND
4FTMAS
Product File No: 20050107

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.40(4)(c)1.b. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2010.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Maximum of four (4) faucets may only be served on one set of shut off valves.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us