



Jim Doyle, Governor
Mary P. Burke, Secretary

March 31, 2005

BRADLEY CORPORATION
THOMAS R EBERHARDY
W142 N9101 FOUNTAIN BLVD
PO BOX 309
MENONMONEE FALLS WI 53052-0309

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: BRADLEY CORPORATION
Product Name: PATIENT CARE UNIT
Model Number(s): LC500, LC700, LC700, LC750, LC800 AND LC2000
Product File No: 20050108

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2010.

This approval is contingent upon compliance with the following stipulation(s):

- When this product has a built-in bedpan washer that has a shut off valve on the discharge, a vacuum breaker meeting ASSE Standard 1056 must be installed in the water supply serving only the bedpan washer. The vacuum breaker must be installed with its critical level at least 12" above the highest point downstream where backpressure would be created.
- When this product has a built-in bedpan washer that does not have a shut off valve on the discharge, a vacuum breaker meeting ASSE Standard 1001 must be installed in the water supply serving only the bedpan washer. The vacuum breaker must be installed with its critical level at least 6" above the highest point downstream where backpressure would be created.

This approval supercedes the approval issued on January 12, 1998, under product file number 19970581.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us