



April 21, 2005

IRON CITY ENTERPRISES, INC.  
TOM NEMETZ  
N 2404 HWY. 41  
MENOMINEE MI 49858

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: IRON CITY ENTERPRISES, INC.  
Product Name: SEPTIC, HOLDING OR PUMP  
Model Number(s): 1000  
(36.0" L.L., 28.8 GAL/IN., 48" MAX. DEPTH OF BURY, 497 G.P.D. WHEN USED AS A  
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL  
WASTEWATER)  
Product File No: 20050116

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2010.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

This approval supersedes the approval issued on INSERT DATE under product file number #####.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

IRON CITY ENTERPRISES, INC.

Page 2

April 21, 2005

Sincerely,

Lee E. Finley, Jr.  
Bureau of Integrated Services  
Department of Commerce  
Phone (608) 261-0450  
Fax (608) 267-9566  
Email [lee.finley@wi.gov](mailto:lee.finley@wi.gov)