



Jim Doyle, Governor
Mary P. Burke, Secretary

April 19, 2005

HUFFCUTT CO., INC.
BILL OLSON
4154 123RD ST
CHIPPEWA FALLS WI 54729

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: HUFFCUTT CO., INC.
Product Name: SEPTIC, HOLDING, PUMP, SIPHON OR GREASE INTERCEPTOR
Model Number(s): 3000
(52.0" L.L., 58.6 GAL/IN., 96" MAX. DEPTH OF BURY, 1459 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20050152

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2010.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This product is approved to use the following:
 - Four, six or eight inch inlet and outlet openings.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - 12-inch access port for holding tanks.
 - Four inch discharge opening in riser.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Metal lockdown cover.
 - Cast-A-Seal and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

HUFFCUTT CO., INC.
Page 2
April 19, 2005
Product File No: 20050152

- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.
- When this product is installed as a septic tank, the minimum distance between the inlet(s) and outlet(s) must be at least equal to the length of the longest wall or the diameter of a circle that has the same surface area of the tank, whichever is less.

This approval supercedes the approval issued on May 30, 2001, under product file number 20010240.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010240.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us