



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

April 21, 2005

ALL AMERICAN HOMES, INC.  
CORPORATE HOUSING GROUP  
PERRY A. LEHRMAN  
309 S. 13TH ST.  
PO BOX 968  
DECATUR IN 46733-0968

ALL AMERICAN HOMES, INC.  
JOHN MEYER  
1551 15TH AVE S E  
PO BOX 219  
DYERSVILLE IA 52040-0219

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: ALL AMERICAN HOMES, INC.  
Product Name: TRENTON SERIES  
Model Number(s): TRE 2836: 3 2.5 STD;3 2.5 B STD;3 2.5 BR STD; 3 2.5 BR B STD  
TRE 2840: 3 2.5 STD; 3 2.5 B STD; 3 2.5 BR STD; 3 2.5 BR B STD  
TRE 2844: 4 2.5 STD; 4 2.5 B STD; 4 2.5 BR STD; 4 2.5 BR B STD  
Product File No: 20050192

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2010.

This approval is contingent upon compliance with the following stipulation(s):

- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The flowing water supply pressure at the point(s) of connection must be at least 43 psig for models TRE 2836 3 2.5 STD, TRE 2836 3 2.5 B STD, TRE 2836 3 2.5 BR STD, TRE 2836 3 2.5 B BR STD, TRE 2844 4 2.5 STD, TRE 2844 4 2.5 B STD, TRE 2844 4 2.5 BR STD, TRE 2844 4 2.5 B BR STD; and 44 psig for TRE 2840 3 2.5 STD, TRE 2840 3 2.5 B STD, TRE 2840 3 2.5 BR STD, TRE 2840 3 2.5 B BR STD.

This approval supercedes the approval issued on September 1, 2000, under product file number 20001010.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20001010.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mbeckwith@commerce.state.wi.us