



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor
Mary P. Burke, Secretary

April 21, 2005

HYDRO SYSTEMS
TIM BUTLER
3798 ROUND BOTTOM RD.
CINCINNATI OH 45244

SPARTAN CHEMICAL COMPANY, INC.
ANN FLAGG
1110 SPARTAN DR.
MAUMEE OH 43537

Re: Description: PROPORTIONER
Manufacturer: SPARTAN CHEMICAL COMPANY, INC.
Product Name: PRESS AND FILL DISPENSING SYSTEMS
Model Number(s): SP3135, SP3137, SP3138, SP3139, SP3144 and SP3639
Product File No: 20050194

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.41 (3)(a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2010.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed with a Spartan Chemical Co., Inc. model 9111 Vent T Connector fitting permanently connected to the inlet of the hose serving this product when the product is not served by a separate water supply connection.

This approval supercedes the approval issued on INSERT DATE under product file number #####.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #####.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us