



Jim Doyle, Governor
Mary P. Burke, Secretary

April 21, 2005

KNIGHT, LLC
ANTHONY BOUSE
20531 CRESCENT BAY DRIVE
LAKE FOREST CA 92630

Re: Description: PROPORTIONER
Manufacturer: KNIGHT, LLC
Product Name: MAX-IT CENTER WITH AIRE GAP
Model Number(s): MX-101, PART # 7114121-A; MX-101P, PART # 7114121-PA;
MX-102, PART # 7114122-A; MX-102P, PART # 7114122-PA;
MX-103, PART # 7114123-A; MX-103P, PART # 7114123-PA;
MX-104, PART # 7114124-A; MX-105, PART # 7114125-A;
MXC-401, PART # 7116341; MXC-401-2, PART # 7116342; AND
MXC-404, PART # 7116344
Product File No: 20050196

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.41 (3) (a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2010.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed with a non-valve "Y" connector with one outlet of the connector permanently connected to the inlet hose serving this product and the other outlet of the connector permanently capped with a cap having a 0.078 diameter hole when this product is not served by a separate water supply connection.

This approval supercedes the approval issued on October 27, 2000, under product file number 20002121.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20002121.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us