



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

August 29, 2005

AK INDUSTRIES, INC.  
POLY/SEPTIC  
KURT A. SNEARLY  
PO BOX 640  
PLYMOUTH IN 46563

Re: Description: SEWAGE TANKS, POLYETHYLENE  
Manufacturer: AK INDUSTRIES, INC.  
Product Name: SEPTIC  
Model Number(s): AKS 40249 -500 GALLON  
(29" L.L., 24" MAX. DEPTH OF BURY, 242 G.P.D. WHEN USED AS A SEPTIC TANK  
BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)  
Product File No: 20050214

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2010.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the tank.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.
- When wastewater from this tank is discharge to a POWTS treatment or dispersal component that consist in part of unsaturated soil, provisions must be made to remove any solid or suspended solid exceeding 1/8-inch in diameter before the wastewater is discharged the soil component.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mbeckwith@commerce.state.wi.us