



Jim Doyle, Governor
Mary P. Burke, Secretary

May 20, 2005

FAIRMONT HOMES INC
CHAD REEVE
502 S OAKLAND AVE
NAPPANEE IN 46550

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: FAIRMONT HOMES INC
Product Name: PFPS TREES
Model Number(s): DWV; A, B, C, D, E, F, G and WATER; TUB/SHOWER, STOOL, CLOTHES WASHER,
KITCHEN SINK, KITCHEN SINK WITH DISHWASHER, and LAVATORY
Product File No: 20050286

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2010.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 15 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The air admittance valve must be an approved product by this office and installed in accordance with its approval by this office.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us