



Jim Doyle, Governor
Mary P. Burke, Secretary

June 9, 2005

REV'S PRE-CAST CONCRETE CORP.
DAYNE REVOLINSKI
1410 ELLIS ST.
WAUKESHA WI 53186

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: REV'S PRE-CAST CONCRETE CORP.
Product Name: SEPTIC, HOLDING OR PUMP
Model Number(s): 750
(41.0" L.L., 19.4 GAL/IN., 66" MAX. DEPTH OF BURY, 381 G.P.D. WHEN USED AS A
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20050300

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2006.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This product is approved to use the following:
 - Four inch discharge opening in riser.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Four inch pipe opening in access cover.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.

This approval supercedes the approval issued on August 3, 2001, under product file number 20010277 to John A. Roder Corp.

REV'S PRE-CAST CONCRETE CORP.

Page 2

June 9, 2005

Product File No: 20050300

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010277.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE

Plumbing Product Reviewer

phone: 608-266-6742

fax: 608-267-9566

e-mail: mbeckwith@commerce.state.wi.us